

ESMAP

Global Mini Grid Technical Conference

Abuja, Nigeria, December 6, 2017

FRONTIER DEVELOPMENTS IN MINI GRIDS

Geospatial planning

Ignacio J. Pérez-Arriaga

CEEPR, MIT

Instituto de Investigación Tecnológica (IIT), Comillas University

Florence School of Regulation, European University Institute





MITEi
MIT Energy Initiative


UTILITY OF THE FUTURE

An MIT Energy Initiative response
to an industry in transition


In collaboration with IIT-Comillas



We have to change the “top-down” perspective...



... by another one with demand & generation all over the place



**What could be the true frontier
of mini grids in the developing
world?**

I do believe that mini grids must...
... become integrated as one more
component of a comprehensive
electrification process...
... led by the incumbent distributor

- **The differentiation between grid extension, mini grids & SHS is becoming blurred**
- **An integrated perspective is becoming increasingly necessary**

How can geospatial planning help in the electrification planning process?

What's an electrification plan?

(the techno-economic answer)

- An electrification plan will consist of some **mix of on- & off-grid** expansions providing electricity access to all consumers at **minimum cost**
 - For some **prescribed demand** for each consumer
 - Meeting **minimum reliability requirements**
 - And **additional constraints** (e.g. limit on the total diesel utilization)

The costs of the plan

- The plan will consist of on- & off-grid expansions
- **Grid extension** costs
 - Investment & operation costs of new grid, reinforcements of existing grid, “upstream” cost of grid-supplied electricity, cost of non served energy
- **Off-grid** development costs
 - **Microgrids:** Investment & operation costs of generation, storage & network, cost of non served energy
 - **Stand-alone systems:** Investment & operation costs of generation & storage, cost of non served energy

The Reference Electrification Model (REM)

Massachusetts Institute of Technology / Tata Center for
Technology and Design


IIT-Comillas University / Institute for Research in Technology



Universal Energy Access Lab


<http://universalaccess.mit.edu>

REM supports large-scale electrification planning...



**District of
Vaishali (Bihar)
About 600,000
households**

... as well as local electrification projects...





**Village of Tayabpur, in
Bikhanpura, Desari block, ward
9,(Bihar)
190 households**

- Generation Site
- Low Voltage Network
- Consumers



Cable Type/Name	kVA	Length (km)	Costs (euros)
mole (single phase)	15	1.14	1130.82
gopher (single phase)	27	0.26	495.74
weasel (single phase)	30	0.04	87.21
weasel	89	1.05	3505.63
ferret	107	0.35	1532.83

REM output in both cases


- Network layout
- Generation design (micro-grids), detailed dispatch
- Detailed cost and design figures (tables, charts)
- Geo-referenced solutions (maps)




Low Demand Summary Table:	
Total Cost Annuity	\$1832
Total Capital Costs	\$1405
Annual O&M	7
LV Correction Costs	\$376
LV Prevention Costs	\$358
LV Capital Costs	\$18
Annual Losses (MWH)	\$1405
Annuity/Load Served (\$/kWh)	7
	5.63
	0.032



Large-scale REM output




**District of
Vaishali (Bihar)
About 600,000
households**



Existing 11kV Extension 400V Extension 11kV Microgrid 400V Stand-Alone

We start from the position of every building to be supplied...

**District of
Vaishali (Bihar)
About 600,000
households**




**If geolocation of buildings is not available,
starting from satellite imagery...**



... our software identifies the location of each building...



... we also need the estimated demand for each type of building...




... & the location & characteristics of the existing network...




... & then the REM model determines the lowest cost electrification mode for each building & can place it on Google maps



Once REM determines the electrification mode for each building, we can place the solution on Google maps...




For each microgrid REM optimizes the mix of generation & storage...




... & provides statistics of cost & performance for each type of supply

— Extension 11kV
 — Extension 400V
 — Microgrid 11kV
 — Microgrid 400V
 ● Stand-Alone



System Type	Microgrid	Extension	Stand-Alone
Number of customers	15433	10050	0
Number of systems	11	4	0
Avg. customers per system	1403.00	2512.50	0
Avg. PV array size (kW)	462.99	0	0.16
Avg. battery bank size (kWh)	0	0	0.853
Avg. generator size (kW)	1218.88	0	0
Total system investment & running cost (\$/yr)	1 299 642.00	432 371.00	-
Cost per kWh demand served (\$/kWh)	0.5199	0.3102	0.0000
Avg. fraction of demand served (%)	99.0%	85.0%	0.0%
Annual Non-served Energy Cost (kWh/yr)	3 021.57	140 830.42	-
Administrative costs (\$/yr)	39 089.40	72 462.44	-
Energy Served (kWh/yr)	2 500 003.11	1 393 644.74	-
Energy per customer (kWh/yr)	161.99	138.67	0.00
Annuity per customer (\$/yr)	84.21	43.02	0.00




**... & it can adapt the network layout
to the pattern of roads and paths in
the village**

DETAIL OF THE DESIGN OF ONE MICROGRID

Legend

- ▲ Low/Medium Voltage Transformer
- Low Voltage Consumer
- Medium Voltage Network
- Low Voltage Network

250 0 250 500 750 1000 m




Topography...


(ongoing implementation)

Study Area (Rwanda):


- ~ 100 sq. km
- ~ 2000 Residential Consumers
- Closest “Existing/Ongoing” Line




Topography: NO
Forbidden Zones: NO
Forbidden Zone Cost Multipliers: N/A




Topography: YES
Forbidden Zones: NO
Forbidden Zone Cost Multipliers: N/A



Topography: YES
Forbidden Zones: YES
Forbidden Zone Cost Multipliers: 10



Topography: YES
Forbidden Zones: YES
Forbidden Zone Cost Multipliers: 100



Sensitivity analysis

For both large scale & village levels

The model can be used to answer “**what if questions**” by comparison of various scenarios

For example, how would the optimal electrification mode change if...


- ... grid **reliability** improves?
- ... electricity **demand grows** significantly?
- ... microgrids are required to be built to **grid code**?
- ... some **technology** (e.g. diesel, DC) is excluded?

Uganda

(Southern Territories)

Uganda – Southern territories

Forced 100% Grid Extension




Results obtained with the REM planning model

<http://universalaccess.mit.edu/#/main>

— Extension 11kV — Extension 400V — Microgrid 11kV — Microgrid 400V ● Stand-Alone

Uganda – Southern territories

100% Grid Reliability




Results obtained with the REM planning model

<http://universalaccess.mit.edu/#/main>

— Extension 11kV — Extension 400V — Microgrid 11kV — Microgrid 400V ● Stand-Alone

Uganda – Southern territories

85% Grid Reliability



Cajamarca *(Peru)*

The Cajamarca region

- The region of Cajamarca is located in the north of Peru and close to Ecuador.
- The case study focus on the Michiquillay district.
- It has an area of approximately 400 km² and around 6,700 buildings.





Image source: Andres Gonzalez-Garcia, Reja Amatya, Robert Stoner, and Ignacio Perez-Arriaga, 'Evaluation of universal access to modern energy services in Peru. Case study of scenarios for Electricity Access in Cajamarca.' Enel Foundation, 2015.


Cajamarca (*Peru*)

Location of buildings



Cajamarca (Peru)


Base case (*estimated household demand: 185.5 kWh/year*)



◆ Microgrid generation — Microgrids 400V ● Stand Alone Systems

Cajamarca (Peru)


Demand growth (500 kWh/year & household)



Nigeria

(Identification of best mini grid sites in Sokoto)

Google Earth With UTM regions



- Sokoto region:
 - 2 UTM zones (31/32)
- Village-level boundary data and additional information such as population, number of schools & health centers available

Sokoto State data

- Total population: 4.37 million
- 1,503 clusters (clusters identified using global population dataset, NMIS school data, and polling units)
- Largest cluster 904,798 population – identified as an electrified cluster
- Largest cluster 29,865 population (~ 6000 hh) – identified as unelectrified cluster
- Total number of electrified clusters: 167 (12.5%)
- Total population electrified: 2.33 million (53%)

Assumptions:


- Household population = 5 people (* given population is not a round number – probably came from some statistical measurement)
- Electrified village cluster data provided by the WB (based on nightlight data, and information about electrified schools)

Run 1 (Base case; grid reliability: 85%)

- Grid reliability = 85% (assumption)
- Result: 15% of the demand nodes created should be grid connected as it is the least cost option, rest should be off-grid systems
- At this level of granularity, there is no distinction between a microgrid and an isolated system, as a single isolated system in a green dot would be a microgrid for 100 household customer.

Column1	Microgrids	Isolated Systems	Grid Extensions	All
Number of Customers (#households)	2156	1792	688	4636
Fraction of Customers	0.47	0.39	0.15	1
NPV per Customer (\$)	61756	24422	31340	42811
System Cost Per Customer (\$/yr)	6315.11	3677.07	2628.21	4748.25
Administrative Cost Per Customer (\$/yr)	49.3	60	9.02	47.46
Non-served Energy Cost Per Customer (\$/yr)	8	20.67	3453.2	524.18
Final Cost Per Customer (\$/yr)	6372.41	3757.74	6090.43	5319.89
Total System NPV (\$)	133145465	43764702	21562187	198472353
Total System Cost (\$/yr)	13615377	6589305	1808208	22012890
Total Administrative Cost (\$/yr)	106290	107520	6206	220016
Total Non-served Energy Cost (\$/yr)	17254	37038	2375802	2430095
Final Cost (\$/yr)	13738921	6733863	4190217	24663001
Fraction of Demand Served (p.u.)	1	1	0.85	0.98
Cost Per kWh of Demand Served (\$/kWh)	0.22	0.22	0.13	0.21
Cost Per kWh of Total Demand (\$/kWh)	0.22	0.22	0.11	0.2

Resulting electrification modes




Run 2 (increasing grid reliability to 90%)

- Grid reliability = 90% (assumption)
- Result: 64% of the demand nodes created should be grid connected as it is the least cost option, rest should be off-grid systems


Column1	Microgrids	Isolated System	Grid Extensions	All
Number of Customers	335	1329	2972	4636
Fraction of Customers	0.07	0.29	0.64	1
NPV per Customer (\$)	20956	7358	40843	29807
System Cost Per Customer (\$/yr)	2142.92	1107.77	3425.11	2668.15
Administrative Cost Per Customer (\$/yr)	54.88	60	9.02	26.95
Non-served Energy Cost Per Customer (\$/yr)	10.65	20.37	3272.41	2104.45
Final Cost Per Customer (\$/yr)	2208.44	1188.14	6706.54	4799.55
Total System NPV (\$)	7020161	9778228	121385860	138184249
Total System Cost (\$/yr)	717878	1472230	10179438	12369546
Total Administrative Cost (\$/yr)	18384	79740	26810	124935
Total Non-served Energy Cost (\$/yr)	3566	27074	9725593	9756233
Final Cost (\$/yr)	739828	1579044	19931841	22250714
Fraction of Demand Served (p.u.)	1	0.99	0.9	0.91
Cost Per kWh of Demand Served (\$/kWh)	0.26	0.29	0.11	0.12
Cost Per kWh of Total Demand (\$/kWh)	0.26	0.29	0.1	0.11

Resulting electrification modes



440 village clusters are always electrified via off-grid systems


(even with high reliable grid scenario)



- Clusters in blue boundaries – grid connected
- Clusters in yellow/green – some or all off-grid nodes
- Current granularity level does not allow for distinction between isolation home systems and microgrids – all compiled as off-grid systems
- High priority off-grid project – probably the ones where all demand nodes are served by off-grid systems (440 village clusters)

Now for a single mini grid


(manually identified households from Google Earth)



Chosen cluster

- Cluster NESP_ID 7379
- Population: 833
- Total number of customers (*assumption*):
 - Residential: 170 (Daily energy usage ~ 0.75kWh)
 - Commercial: 43 (Daily energy usage ~ 3.5 kWh)
 - Productive: 17 (Daily energy usage ~ 8.5 kWh)



REM result (with network layout)



REM results (no diesel constraint)

Capital cost:		
	Size	Capital (USD \$)
Solar PV + installation	49 kW	34,300
Battery + installation	-	-
Diesel Generator	20 kW	12,127
Inverter	40 kW	8,192
MPPT Charge controller	-	-
Network + distribution transformers (incl. poles cost)	4.89 km	65,956
Total		120,575
Network (component breakdown)		
Name	Length (km)	Capital (USD \$)
Weasel	4.14	49,638
Ferret	0.30	3,916
Rabbit	0.39	5,513
Dog	0.02	346
Panther	0.04	977

Microgrid (generation/load profile)



Diesel constrained scenario

Limiting the total demand met by diesel generator


20% constraint			No constraint	
Capital cost:				
	Size	Capital (USD \$)	Size	Capital (USD \$)
Solar PV + installation	92.75 kW	64,925	49 kW	34,300
Battery + installation	488 kWh	105,900	-	-
Diesel Generator	5 kW	5,760	20 kW	12,127
Inverter	36 kW	7,532	40 kW	8,192
MPPT Charge controller		9,811		
Network + distribution transformers	4.89 km	65,862	4.89 km	65,956
Total		259,790		120,575
Net Present Value (incl. replacement, O&M, fuel costs: project lifetime = 20 years) **		370,000		183,350

** Does not include network (capital, O&M)

Some other practical constraints of having a diesel generator – such as uncertainty in fuel supply, theft of fuel etc. has not been captured in the cost of running a diesel generator

Any similar models to LittleREM?

Models similar to LittleREM



Any similar models to BigREM?

Models similar to BigREM

- **NP** (Network Planner, from Columbia University)
 - Uses LandScan data & or clusters at village level to describe where population (& therefore demand) are located
 - Therefore less granularity than REM, but still good
 - Only considers one type of medium voltage line
 - Professional interface

Models similar to BigREM

- **LAPER** (Logiciel d' Aide à la Planification de l'Électrification Rurale)
 - Also aggregates consumers into villages and does not design the interior of the village.
 - Therefore less granularity than REM
 - It can consider non-economic criteria
- **NPAM** (Network Performance Assessment Model, from KTH) does clustering to identify locations suitable for microgrids.

Thank you

ESMAP

Global Mini Grid Technical Conference

Abuja, Nigeria, December 6, 2017

FRONTEER DEVELOPMENTSIN MINI GRIDS

Geospatial planning

Ignacio J. Pérez-Arriaga

CEEPR, MIT

Instituto de Investigación Tecnológica (IIT), Comillas University

Florence School of Regulation, European University Institute

