Cs

CASE STUDIES

TOPIC ENERGY EFFICIENCY October 2015





Final Report

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN

October 2015

Published by CAF- Latin America Development Bank Energy Vice-presidency/ Directorate of Analysis and Energy Strategies

Hamilton Moss, Corporate Vice-president Mauricio Garrón, Director Alvaro Atilano, Principal Executive. Study Coordinator

Prepared By MAKAI OCEAN ENGINEERING, INC.

The ideas and proposals contained in this issue are the exclusive responsibility of the authors and do not reflect the official position of CAF.

© 2015 Corporación Andina de Fomento



TABLE OF CONTENTS

LIST OF FIGURES III LIST OF TABLES IV 1. INTRODUCTION 6 1.1. PURPOSE OF STUDY. 6 1.2. METHOD OF STUDY. 6 1.3. CONCEPTUAL DESIGN 7 1.4. REPORT. 7 1.5. CONCLUSIONS OF STUDY. 8 2. SITE DATA 10 2.1.1. System Design 10 2.1.2. Offshore Data 11 2.1.3. Optimization 12 2.2. PUERTO PLATA 14 2.2.1. System Design 14 2.2.2. Offshore Data 11 2.1.3. Optimization 15 3. MODELING RESULTS 17 3.1. Technical Output 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2. Cos	TABLE	OF CONT	ENTS	I
LIST OF TABLES. IV 1. INTRODUCTION 6 1.1. PURPOSE OF STUDY 6 1.2. METHOD OF STUDY 6 1.3. CONCEPTUAL DESIGN 7 1.4. REPORT 7 1.5. CONCLUSIONS OF STUDY. 8 2. SITE DATA 10 2.1. MONTEGO BAY 10 2.1.1. System Design 10 2.1.2. Offshore Data 11 2.1.3. Optimization 12 2.2. PUERTO PLATA 14 2.2.1. System Design 14 2.2.2. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.1. Technical Output 22 3.2.1. </td <td>LIST O</td> <td>F FIGURE</td> <td>S</td> <td>. 111</td>	LIST O	F FIGURE	S	. 111
1. INTRODUCTION 6 1.1. PURPOSE OF STUDY. 6 1.2. METHOD OF STUDY. 6 1.3. CONCEPTUAL DESIGN 7 1.4. REPORT 7 1.5. CONCLUSIONS OF STUDY. 8 2. SITE DATA	LIST O	F TABLES	5	.IV
1.1. PURPOSE OF STUDY.	1.	INTRODU	ICTION	6
1.2. METHOD OF STUDY.	1.1.	PURPO	DSE OF STUDY	6
1.3. CONCEPTUAL DESIGN 7 1.4. REPORT. 7 1.5. CONCLUSIONS OF STUDY. 8 2. SITE DATA	1.2.	METHO	DD OF STUDY	6
1.4. REPORT	1.3.	CONCE	EPTUAL DESIGN	7
1.5. CONCLUSIONS OF STUDY. 8 2. SITE DATA	1.4.	REPOF	RT	7
2. SITE DATA	1.5.	CONCL	LUSIONS OF STUDY	8
2.1. MONTEGO BAY	2.	SITE DAT	Α	10
2.1.1. System Design 10 2.1.2. Offshore Data 11 2.1.3. Optimization 12 2.2. PUERTO PLATA 14 2.2.1. System Design 14 2.2.2. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS. 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT. 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44	2.1.	MONTE	EGO BAY	10
2.1.2. Offshore Data 11 2.1.3. Optimization 12 2.2. PUERTO PLATA 14 2.2.1. System Design 14 2.2.2. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1. MONTEGO BAY 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 36 5.1.2. Hybrid SWAC 44 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 48 <t< td=""><td></td><td>2.1.1.</td><td>System Design</td><td>10</td></t<>		2.1.1.	System Design	10
2.1.5. Optimization 12 2.2. PUERTO PLATA 14 2.2.1. System Design 14 2.2.2. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1. MONTEGO BAY 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Electrical Cost 35 5.1.1. Looling Load 36 5.1.3. Thermal Energy Storage 44 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 48 </td <td></td> <td>2.1.2.</td> <td>Offshore Data</td> <td>11</td>		2.1.2.	Offshore Data	11
2.2.1. System Design 14 2.2.2. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1. MONTEGO BAY 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 36 5.1.3. Thermal Energy Storage 44 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 48<	2.2	Z. I.J. DI IERT		17
2.2.1. Offshore Data 14 2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1. MONTEGO BAY 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2.1. Electrical Cost 36 5.2.2. Cooling Load 36 5.2.3. Hybrid SWAC 51 5.2.4. Thermal Energy Storage 54 6. RISK ANALYSIS 50 </td <td>2.2.</td> <td>221</td> <td>System Design</td> <td>14</td>	2.2.	221	System Design	14
2.2.3. Optimization 15 3. MODELING RESULTS 17 3.1. MONTEGO BAY 17 3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2.1. Electrical Cost 36 5.1.2. Hybrid SWAC 51 5.2.1. Electrical Cost 36 5.1.2. Hybrid SWAC 51 5.2.4. Thermal Energy Storage 54 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 5		2.2.2.	Offshore Data	14
3. MODELING RESULTS		2.2.3.	Optimization	15
3.1. MONTEGO BAY	3.	MODELIN	IG RESULTS	17
3.1.1. Technical Output 17 3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 44 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60	3.1.	MONTE	EGO BAY	17
3.1.2. Costs 19 3.2. PUERTO PLATA 21 3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.1. Electrical Cost 40 5.1.3. Thermal Energy Storage 44 5.2. Cooling Load 51 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60		3.1.1.	Technical Output	17
3.2. PUERTO PLATA		3.1.2.	Costs	19
3.2.1. Technical Output 22 3.2.2. Costs 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60	3.2.	PUERT	TO PLATA	21
3.2.2. COSIS 24 4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60		3.2.1.	Technical Output	22
4. SWAC SYSTEM CONCEPTUAL DESIGN 28 4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60	4	3.2.2.		24
4.1. OVERVIEW 28 4.2. DISTRIBUTION SYSTEM LAYOUT. 30 5. SENSITIVITY ANALYSIS. 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60	4.	SWAC SI		28
4.2. DISTRIBUTION SYSTEM LAYOUT 30 5. SENSITIVITY ANALYSIS 35 5.1. MONTEGO BAY 35 5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60	4.1.	OVER		28
5. SENSITIVITY ANALYSIS	4.2.	DISTRI		30
5.1. MONTEGO BAY	5.	SENSITIV	/ITY ANALYSIS	35
5.1.1. Electrical Cost 35 5.1.1. Cooling Load 36 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56	5.1.	MONTE	EGO BAY	35
5.1.1. Cooling Load 30 5.1.2. Hybrid SWAC 40 5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56		5.1.1.	Electrical Cost	35
5.1.3. Thermal Energy Storage 44 5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56		5.1.2.	Hybrid SWAC	40
5.2. PUERTO PLATA 48 5.2.1. Electrical Cost 48 5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60		5.1.3.	Thermal Energy Storage	44
5.2.1. Electrical Cost	5.2.	PUERT	O PLATA	48
5.2.2. Cooling Load 51 5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60		5.2.1.	Electrical Cost	48
5.2.3. Hybrid SWAC 53 5.2.4. Thermal Energy Storage 56 6. RISK ANALYSIS 60		5.2.2.	Cooling Load	51
6. RISK ANALYSIS 60		5.2.3. 5.2.4	Thermal Energy Storage	53 56
	6.	RISK AN	ALYSIS	60



	6.1.1. 6.1.2. 6.1.3.	Montego Bay Puerto Plata Risk Mitigation	60 61 61
6.2.	EARTH	QUAKES	61
	6.2.1. 6.2.2. 6.2.3.	Montego Bay Puerto Plata Risk Mitigation	61 64 66
6.3.	BUILDI	NG RETROFIT	66
7.	MARKETI	NG PLAN	69
7.1.	CUSTC	MER PROFILES	69
	7.1.1.	Load Segmentation	69
7.2.	SWAC	DEVELOPMENT STRATEGY	70
	7.2.1. 7.2.2.	Developer Interest Market Preparation	70 70
7.3.	CUSTC	MER-UTILITY RELATIONSHIP	72
	7.3.1. 7.3.2.	Customer Requirements Rate Structure	72 72
8.	CONCLU	SIONS	75
8.1.	MONTE	EGO BAY	75
8.2.	PUERT	O PLATA	75



LIST OF FIGURES

Figure 1-1: Figure 2-1	Simplified schematic of the SWAC model iteration cycle	6
Figure 2-2:	Nautical chart for zone off Montego Bay. The red line represents a potential pipe path	.10
Figure 2.2	With the shortest distance to deep water	.11
Figure 2-3.	Dathymetry and seawater temperature promes used for Montego Day	.12
Figure 2-4.	Neutricel chart for some of Duarte Diate. The read line represente a notantial minaline noth	.14
Figure 2-5:	Nautical chart for zone of Puerto Plata. The red line represents a potential pipeline path	15
Figure 2 C	Pethymetry and accurate temperature profiles used for Duorte Diete	.15
Figure 2-6:	Bathymetry and seawater temperature profiles used for Puerto Plata	.15
Figure 4-1:	conventional AC (left)	.28
Figure 4-2:	HDPE fusion used to join two lengths of pipe during the assembly process	.29
Figure 4-3:	Controlled submergence of an HDPE pipe designed by Makai	.29
Figure 4-4:	Aerial image of the NELHA sump-style pump station, located in Kona, HI, USA	.30
Figure 4-5:	Conceptual Distribution Piping Layout in Montego Bay	.31
Figure 4-6:	Conceptual Distribution Piping Layout in Puerto Plata	.32
Figure 4-7:	Distribution Pipe Installed under a Roadway	.32
Figure 4-8:	Typical closed loop trench connection	.33
Figure 4-9:	Installation of Distribution Pipe around Existing Utilities	.34
Figure 5-1:	Comparison of the Effect of Electrical Rate on SWAC (blue) and Conventional AC (red)	
	in Montego Bay in levelized cost units of \$/ton/year	.35
Figure 5-2:	Comparison of the Effect of Load Factor on SWAC and Conventional AC in Montego	
-	Bay	.38
Figure 5-3:	Schematic of Pure SWAC	.41
Figure 5-4:	Schematic of Hybrid SWAC	.41
Figure 5-5:	The Effect of Hybrid SWAC on Levelized Cost in Montego Bay	.42
Figure 5-6:	Diagram of Chilled Water Storage Operation	.45
Figure 5-7:	The Effect of TES Tank Capacity on SWAC Levelized Cost in Montego Bay	.46
Figure 5-8:	Comparison of the Effect of Electrical Rate on SWAC and Conventional AC in Puerto	
	Plata	.49
Figure 5-9:	Comparison of the Effect of Load Factor on SWAC and Conventional AC in Puerto	~ 1
Figure E 10	The Effect of Hubrid SWAC on Levelized Cost in Duorte Plate	.51
Figure 5-10.	The Effect of TES Tank Conseity on SWAC Levelized Cost in Puerto Plata	.54
Figure 5-11:	The Effect of TES Tank Capacity on SWAC Levelized Cost in Puerto Plata	.57
Figure 6-1:	Major Hurricanes near Jamaica Since 1842	.60
Figure 6-2.	Trajor Humcanes near the Dominican Republic Since 1642	.01
Figure 6-3:	Earthquakes hear Jamaica since 1900	.62
Figure 6-4:	GSHAP Seismic Hazard Map of Jamaica	.63
Figure 6-5:	Earthquakes hear the Dominican Republic Since 1900	.64
Figure 6-6:	GOMAY Seisinic Hazard Iviap of the Dominican Republic	.65
Figure 6-7:	Example of a Rooitop Air Handling Unit	.66
Figure 6-8:	Example of Iviini-Split Air Conditioning Systems	.67
Figure 6-9:	Example of window Unit Air Conditioners	.67



LIST OF TABLES

Table 2-1:	Additional Cooling Data Obtained for Montego Bay	12
Table 2-2:	Potential Cooling Customers and Loads in Montego Bay	13
Table 2-3:	Potential Cooling Customers and Loads in Puerto Plata	16
Table 3-1:	Technical Results of SWAC Modeling for Montego Bay (abbreviated for public	
	release)	18
Table 3-2:	Summary of Levelized Cost for a SWAC System in Montego Bay	19
Table 3-3:	Summary of Capital Costs for a SWAC System in Montego Bay (abbreviated for public release)	20
Table 3-4:	Summary of Operating Cost of a SWAC System in Montego Bay (abbreviated for public release)	21
Table 3-5:	Summary of Conventional Air Conditioning Costs in Montego Bay	21
Table 3-6:	Technical Results of SWAC Modeling for Puerto Plata (abbreviated for public release).	23
Table 3-7:	Summary of Levelized Cost for a SWAC System in Puerto Plata	24
Table 3-8:	Summary of Capital Costs for a SWAC System in Puerto Plata (abbreviated for public release)	
Table 3-9:	Summary of Operating Cost of a SWAC System in Puerto Plata (abbreviated for	
	public release)	26
Table 3-10:	Summary of Conventional Air Conditioning Costs in Puerto Plata	26
Table 5-1:	Cost Output of Montego Bay Electrical Rate Sensitivity Study	37
Table 5-2:	Cost Output of Montego Bay Load Factor Sensitivity Study (abbreviated for public release)	39
Table 5-3:	Technical Output of Montego Bay Load Factor Sensitivity Study (abbreviated for public release)	40
Table 5-4:	Cost Output of Montego Bay Hybrid SWAC Sensitivity Study	43
Table 5-5:	Technical Output of Montego Bay Hybrid SWAC Sensitivity Study	44
Table 5-6:	Cost Output of Montego Bay TES Tank Sensitivity Study	47
Table 5-7:	Technical Output of Montego Bay TES Tank Sensitivity Study	48
Table 5-8:	Cost Output of Puerto Plata Electrical Rate Sensitivity Study	50
Table 5-9:	Cost Output of Puerto Plata Load Factor Sensitivity Study	52
Table 5-10:	Technical Output of Puerto Plata Load Factor Sensitivity Study	53
Table 5-11:	Cost Output of Puerto Plata Hybrid SWAC Sensitivity Study	55
Table 5-12:	Technical Output of Puerto Plata Hybrid SWAC Sensitivity Study	56
Table 5-13:	Technical Output of Puerto Plata TES Tank Sensitivity Study	58
Table 5-14:	Technical Output of Puerto Plata TES Tank Sensitivity Study	59
Table 6-1:	GSHAP Peak Ground Acceleration Estimates near Montego Bay	63
Table 6-2:	GSHAP Peak Ground Acceleration Estimates near Puerto Plata	65
Table 7-1:	Load Segmentation in Montego Bay	69
Table 7-2:	Load Segmentation in Puerto Plata	69





1. **INTRODUCTION**

1.1. PURPOSE OF STUDY

At CAF request, Makai Ocean Engineering Incorporated (Makai) has completed a study on the use of cold deep seawater for air conditioning (SWAC) at two sites in the Caribbean; Montego Bay, Jamaica and Puerto Plata, Dominican Republic. Initially 8 Caribbean sites were evaluated for SWAC development, selecting these two sites for more detailed analysis based on their lowest levelized lifetime cost for installing and operating a SWAC system.

The feasibility study of these two sites, presented in this report, includes a preliminary conceptual design for the seawater intake and return pipes, pump station, chilled water distribution system, and estimates of capital cost, operating cost, and levelized cost book life analysis.

1.2. <u>METHOD OF STUDY</u>

During the past 20 years Makai has developed a numerical tool to more effectively enable the preliminary design and cost estimation of SWAC systems for their clients. The tool, referred to as the SWAC Model, uses a limited number of inputs such as individual cooling loads, offshore bathymetry, and other site conditions to compute a basic conceptual design for the entire SWAC system.

The SWAC model iterates on the size of the SWAC system components, location and depth of intake, and water flow rates until all end users of the district cooling system are provided a satisfactory supply water temperature, water pressure, and cooling load. The model incorporates hydraulics throughout the system, temperature gains, and oceanographic site conditions to compute SWAC operating parameters for district cooling systems ranging from just a few individual loads and supply pipelines.

Figure 1-1 shows a simplified schematic of the iteration process. The SWAC model was used for the analysis of Montego Bay and Puerto Plata.



Figure 1-1: Simplified schematic of the SWAC model iteration cycle.

The output from the SWAC model includes the critical design parameters for an intake pipeline, a pump/heat exchanger station, an onshore chilled water distribution network, and a discharge pipeline. The software then computes a cost for the design, construction, and long term operation of the SWAC system. The capital costs are estimated using methods similar to marine and civil contractors, with estimates broken down by major equipment, specific labor, and materials. A detailed construction schedule is computed by the SWAC model, which in turn determines the time usage and cost of major equipment, materials requirements, and labor for the project. Overall, the model incorporates the unit costs for over 160 articles of equipment and materials, and 15 different labor rates, which are then applied across cost estimates for 17 fundamental construction steps.



For this study Makai worked with local contacts to obtain building load data directly from building operators. The study included an assessment of auxiliary chillers and thermal energy storage (TES). TES has been used in district cooling networks to offset peak cooling demand, and has the potential to reduce the size of the offshore intake pipeline. With TES, cold water is slowly drawn out of the system and pumped into a large storage tank during off-peak hours and is discharged back into the system during peak hours. The use of a traditional chiller with SWAC, referred to as auxilliary chilling, can be used to additionally cool the SWAC supply water in order to reduce the offshore pipe size or depth requirements. In some instances, where the relative costs for larger or longer pipes are high, these systems can reduce the liftetime costs of the seawater cooing system.

Both auxiliary chillers and TES allow cold water intake systems to be designed for less than the peak usages. These systems are not beneficial for all networks, and due to the dependencies among the various system components, a numerical model is required to properly assess the consequences and economics of these design options.

1.3. <u>CONCEPTUAL DESIGN</u>

The modeling study resulted in a conceptual design for each site with a lowest levelized cost. For these scenarios additional design details were provided. The conceptual designs are based on past design experience and pipeline installations. The conceptual designs include descriptions of the:

- Anchoring Designs and Hydrodynamic Loads
- Construction Process
- Installation Process
- Shore Crossing Methods
- Pump Station
- Heat Exchangers

1.4. REPORT

The remainder of this report summarizes the detailed analysis done on SWAC systems at Montego Bay, Jamaica, and Puerto Plata, Dominican Republic. The report describes:

- 1. Summary of site data and cooling customer data collected since the preliminary analysis phase.
- 2. More detailed modeling and optimization using Makai's SWAC model, including analysis of hybrid SWAC and thermal energy storage systems.
- 3. Conceptual design of each SWAC system, provided as an abbreviated overview of our design process and examples that have been successfully applied in other projects.
- Sensitivity studies investigating the impact of variations in electrical rate, variations in cooling load, inclusion of hybrid SWAC, and addition of thermal energy storage on the levelized cost of SWAC at each site.
- 5. Risk analysis investigating the possibility of hurricanes and earthquakes that could pose a threat to the SWAC system.
- 6. General marketing plan to guide CAF in encouraging SWAC development in the Caribbean.



1.5. <u>CONCLUSIONS OF STUDY</u>

A section of concluding remarks in the last chapter of this report summarizes the results of the modeling efforts and conceptual designs. It was found that SWAC is economically viable and competitive against conventional air conditioning at the Puerto Plata and Montego Bay sites. The Highlights of the conclusions of this report include:

1. A SWAC system in Montego Bay is estimated to have a capital cost of about \$100 million (USD) and supply about 7600 tons of cooling. Levelized costs are estimated to be 34% lower than conventional AC systems at \$3,458/ton/year.

Cost Summary				
System Specifications				
Peak AC Load (Tons)	7,676			
Average AC Load (Tons)	4,732			
Cost of Electricity (\$/kW-h)	0.36			
Levelized Cost (\$/ton/year)				
SWAC Capital Cost	2,235			
SWAC Operating Cost	1,140			
SWAC Periodic Costs	82			
SWAC Total	3,458			
Conventional AC	5,247			

2. A SWAC system in Puerto Plata is estimated to have a capital cost of about \$68 million (USD) and supply about 6800 tons of cooling. Levelized costs are estimated to be 48% lower than conventional AC systems at \$2,435/ton/year.

Cost Summary	
System Specifications	
Peak AC Load (Tons)	6,835
Average AC Load (Tons)	4,438
Cost of Electricity (\$/kW-h)	0.32
Levelized Cost	(k\$/ton/year)
SWAC Capital Cost	1,626
SWAC Operating Cost	748
SWAC Periodic Costs	61
SWAC Total	2,435
Conventional AC	4,691

- 3. Puerto Plata is shown to benefit from the use of a thermal energy storage system to offset peak load hours.
- 4. Both sites are sensitive to changes in cooling load and electrical rate, but the levelized cost of SWAC remains lower than conventional AC even if the cooling load is ½ that assumed in this analysis.
- Resort hotels at both sites are wary of inquiries relating to cooling equipment, cooling cost, and energy use. Makai recommends that CAF include local stakeholders in the SWAC planning process.



- 6. Both sites are at risk for a direct hit from a category 5 hurricane. The SWAC systems should be designed to handle the loads associated with such a storm. The offshore pipe will likely require post-deployment anchoring in the shallower near shore zones. Previous pipelines have been designed to handle these types of hydrodynamic loads.
- Installation of a SWAC system is expected to be technical viable, but actual costs and feasibility of the system will depend on more detailed bathymetric and site conditions. Makai has designed and installed deep HDPE intake pipes in conditions similar to those expected offshore at both sites.



2. SITE DATA

This section summarizes the site data collection performed to support the feasibility SWAC study at Montego Bay and Puerto Plata. Bathymetric and oceanographic data collection was collected from publically available resources to support a feasibility level study. Wave estimates were obatined from available wave model hindcasts, and Makai estimated extreme storm waves from a parametrization of hurricane force winds and fetches. Makai coordinated with local contacts to collect AC usage data at each site. Success collecting additional data was limited. The majority of potential cooling customers at both sites were unwilling to share information with our team. These customers viewed SWAC is a disruptive technology, fearing it could change the local cooling and energy usage industries.

2.1. MONTEGO BAY

Montego Bay is characterized by a large resort area. There is a cluster of cooling load within Montego Bay itself, and a large number of luxury resorts spread along the north coast. The nearby Bogue Power Station also represents a potential cooling customer if SWAC-powered gas turbine inlet cooling is installed, but has not been included in this analysis. Most of the resorts are modern enough and already make use of chilled water cooling system. These buildings would connect to a district cooling SWAC system with minimal retrofit. A few of the cooling customers may use rooftop or split-unit cooling systems, which would require retrofit before they could be connected to a SWAC system. Retrofit costs were not included in the SWAC analysis presented in this report. For additional information on retrofit costs, see Section 6.3.

2.1.1. System Design

The cold seawater intake pipe landing site was placed in the middle of the available cooling load to minimize the size of the distribution pipes heading east and west. Figure 2-1 shows a schematic of the onshore network connecting all of the cooling loads. Details of the distribution network layout and conceptual design are loacted in Section 4.2.



Figure 2-1. Onshore Cooling Network in Montego Bay



2.1.2. Offshore Data

The publically available offshore data to support pipeline design was limited for both sites under consideration. Additional data would be needed to support a final design of the seawater supply systems.

In Figure 2-2, an excerpt from a nautical chart of Jamaica is shown with the focus being the zone around Montego Bay. The red line on this chart represents the pipe path assumed in our SWAC modeling. This chart can provide some very limited depth data versus distance from shore. These data were used to plot a profile of depth as a function of distance from shore of the assumed pipe route which is shown in the blue curve in Figure 2-3. The chart indicates a shallow reef zone for the first 1 km of the path, after which the bottom drops away into deep water at an average slope of about 14°. It is unlikely that the seabed actually drops off in a straight line as shown in the profile. There is not enough data in the nautical chart to determine the actual shape of the seabed, so the average slope has been used for the analysis.



Figure 2-2: Nautical chart for zone off Montego Bay. The red line represents a potential pipe path with the shortest distance to deep water

The magenta line in Figure 2-3 is a plot of the seawater temperature versus depth. The temperature data are not specific to this Montego Bay site, but are from the closest site to Montego Bay in the World Ocean Atlas data base. The deep water temperatures are unlikely to vary significantly from one site to another when the latitudes are similar, which they are in this case.





Figure 2-3: Bathymetry and seawater temperature profiles used for Montego Bay

2.1.3. Optimization

Several iterations of the SWAC model were run prior to determing the most economical solution. It was found that the Hilton Rose Hall, the Palmyra, and the Ritz-Carlton resorts do not contribute to SWAC system profitability. They are located too far from the seawater intake, and the cost of the distribution piping required to serve them exceeds the benefits from an economy of scale. Therefore those customers are not included in the results that follow.

Table 2-1 lists additional data obtained. Makai relied on the cooling load estimates developed during the preliminary analysis for the all other potential cooling customers.

Client	Actual Installed Load (tons)	SWAC Load Used (tons)	Cooling Equipment	
Holiday Inn Sunspree	500	500	Mini-split and Air Handling Units	
Sunset Beach Resort	400	400	Mini-split and Air Handling Units	
Half Moon Resort	600	600	Mini-splits, Air Handling Units, and Window Units	
Hilton	800	533	Chilled Water	

	Table 2-1:	Additional	Cooling	Data	Obtained	for Mc	ontego	Bay
--	------------	------------	---------	------	----------	--------	--------	-----

Of the three resorts that shared data, only the Hilton has a system that could be conveniently connected to a SWAC system without retrofit. The other three resorts will need to modify the cooling systems within their buildings to take advantage of a SWAC system. See section 6.3 for a discussion of the economic impact of building retrofit.



It has been assumed that the actual cooling requirement at the Hilton is 2/3 of the reported capacity, and that the actual cooling requirement at the other resorts is equal to the installed load. Chilled water cooling systems are typically installed with 1.5x the required capacity. This allows cooling equipment to be taken offline for maintenance while still providing the required cooling.

The total cooling load of the Montego Bay network was 7676 tons.

Table 2-2 shows all the cooling customers and loads used for the Montego Bay analysis.

 Table 2-2:
 Potential Cooling Customers and Loads in Montego Bay

Client	# Rooms	# Suites	Elevation (m)	Load (tons)
Montego Bay Airport			3	1500
Sandals Montego Bay	250	?	5	300
Hotel Riu Palace Jamaica	238	?	3	286
Hotel Riu Montego Bay	681	?	3	817
Sandals Royal Caribbean	197	?	1	236
Holiday Inn SunSpree Resort Montego Bay	520	27	1	500
Sea Garden Beach Resort	140	?	6	168
Royal Decameron Montego Beach	143	?	3	172
University of Technology			8	500
El Greco Resort	58	35	53	154
Wexford Montego Bay	80	?	18	96
Montego Bay Freezone			3	100
The Oasis at Sunset	124	8	3	168
Sunset Beach Resort and Waterpark	430	7	2	533
Secrets St. James Montego Bay	350	?	3	420
Secrets Wild Orchid Montego Bay	700	8	4	859
Bogue Power Station			13	400
Half Moon Resort	398	?	12	600
			Total	7676



2.2. <u>PUERTO PLATA</u>

Puerto Plata is a dense resort area. A large number of luxury resorts are clustered in the Playa Dorada complex, with other resorts nearby. Similar to Montego Bay, most of the resorts are modern enough to make use of chilled water cooling systems and could connect to SWAC with minimal retrofit.

2.2.1. System Design

The cold seawater intake pipe landing site was placed on the peninsula that houses the Playa Dorada complex near the highest density of cooling load. Figure 2-4 shows a schematic of the onshore network connecting all of the cooling loads and the landing site of the offshore pipe.



Figure 2-4. Onshore Cooling Network in Puerto Plata

2.2.2. Offshore Data

An excerpt from a nautical chart of the water around the Dominican Republic is shown in Figure 2-5. The red line is the pipeline alignment assumed in our modeling for this site. The alignment provides the shortest path to deep water from the selected shore crossing location.

14





Figure 2-5: Nautical chart for zone of Puerto Plata. The red line represents a potential pipeline path with the shortest distance to deep water.

In Figure 2-6, the bathymetric profile (in blue) and the deep water temperature profile (in magenta) are presented for Puerto Plata. With a few more bathymetric data points than was available for the Montego Bay site, the offshore bottom profile shows more variation and slope changes. There is a near shore fringing reef that extends out 2 km. Then the bottom drops off quickly with varying slopes out to deep water. The maximum slope is about 14°. Although there is more detail in Figure 2-6 than Figure 2-3, it is still unlikely that the nautical chart accurately captures the actual shape of the seabed along the pipe path needed for final design. The temperature versus depth profile is taken from the World Ocean Atlas at a point as near to Puerto Plata as possible.



Figure 2-6: Bathymetry and seawater temperature profiles used for Puerto Plata

2.2.3. Optimization

The estimated cooling loads developed during the preliminary analysis were used for all potential cooling customers. Table 2-3 shows the cooling customers and loads used in the Puerto Plata analysis. A preliminary optimization of the cooling customers revealed that all of the customers contribute to system profitability. The total cooling load of the network was 6835 tons.



Client	# Rooms	# Suites	Estimated Load (tons)
Paradise Beach	280	145	685
Gran Ventana	167	173	615
Gran Ventana 2	166	0	200
Barcelo	386	199	940
Casa Colonial	0	50	120
Playa Dorada Mall	80	?	100
Blue Bay Villas	0	245	440
Fun Royale	184	?	220
Caribbean Village	336	?	400
Dorada Club	206	?	250
Celusima Playa Naco	200	14	515
Viva Wyndam	84	120	390
Puerto Plata Village	340	46	520
Blue Jack Tar Hotel	69	6	100
Iberostar	498	18	640
Be Live Grand Marien	584	?	700
Total:			6835

Table 2-3: Potential Cooling Customers and Loads in Puerto Plata



3. **MODELING RESULTS**

During a preliminary study (not shown in this report), it was found Montego Bay and Puerto Plata to be the lowest levelized cost sites of the 8 Caribbean sites chosen for study. This chapter describes the results from additional study of the Montego Bay and Puerto Plata sites. In the case of Montego Bay, the cooling customer loads were updated with the new information from Makai's local contacts, summarized above in Table 2-2 and Table 2-3. At both sites a more detailed modeling effort was undertaken that included refined cooling curves (AC usage throughout the day), inclusion of hybrid SWAC (auxiliary chillers) and thermal energy storage systems, and sensitivity studies on varying electrical rates and assumed building loads.

3.1. MONTEGO BAY

The detailed modeling in Montego Bay made use of updated cooling customer loads and adjusted cooling load curves. Makai also updated the cooling load curve for the Bogue Power Station, Airport, Freezone, and University of Technology. It was assumed that the cooling load for the power station is uniform throughout the day, and only varies seasonally. The cooling load for the other customers has been updated to reflect the fact that they are commercial businesses rather than resorts.

It was also considered two alternative SWAC system designs for Montego Bay: a hybrid SWAC system that makes use of chillers to augment seawater cooling, and the inclusion of a thermal energy storage tank. Neither option reduced the levelized cost of SWAC for the site, so they have not been included in the conceptual design or sensitivity studies for the site. See section 5.1.2 for a discussion of hybrid SWAC in Montego Bay, and section 5.1.3 for a discussion of thermal energy storage.

3.1.1. Technical Output

Table 3-1 shows the technical details of the modeled system. The schematic shows the temperature, pressure, and water flow throughout the water distribution system. The technical output of Table 3-1 shows the specifications and operating conditions of the major SWAC components including the offshore pipe dimensions, pump station parameters, heat exchangers, and the freshwater distribution piping.

A SWAC system in Montego Bay requires a seawater intake pipe that is 1200 mm in diameter, 4.5 km long, and reaches to 879 m water depth. The discharge pipe is 1000 mm in diameter and 1.1 km long in order to reach 50 m water depth. The seawater pump station must be excavated such that the pumps can be located 2.2 m below sea level. Table 3-1 has been abbreviated for public release.



Table 3-1: Technical Results of SWAC Modeling for Montego Bay (abbreviated for public release)

Technical Summary		
Scenario	1	
Peak AC Load (Tons)	7676	
Average AC Load (Tons)	4732	
ntake Pipe		Chilled Water Pump Station
Depth of Intake (m)	-879	Total Flow (kg/s)
Length of Intake Pipe (m)	4472	Pump Supply Head (kPa)
Outside Diameter of Intake Pipe (m)	1.20	Pump Return Head (kPa)
Shoreline DR		Pump Head (kPa)
Intake DR		Head Loss Through Heat Exchanger (kPa)
Equivalent DR		Head Loss Through Distribution (kPa)
Deep Water Temperature (°C)	6.19	Freshwater pumping power (kW)
Temperature at Pump Station (°C)		
Shore Crossing Type		Freshwater Distribution System
Average Flow Velocity (m/s)		Maximum User CW Temperature (°C)
Total Pipe Suction Head (kPa)		Minimum User CW Temperature (°C)
Static Head (kPa)		Maximum Pipe Pressure (kPa)
Flow Losses (kPa)		Minimum Pipe Pressure (kPa)
		Maximum User dH (kPa)
leturn Pipe		Minimum User dH (kPa)
Depth of Return (m)	-50	TES Tank Capacity (Miters)
Length of Return Pipe (m)	1092	
Outside Diameter of Return Pipe (m)	1.00	Heat Exchangers
Return Pipe DR		SW dT Across Heat Exchanger (°C)
Max Temperature of Returned Water (°C)		FW dT Across Heat Exchanger (°C)
Flow Velocity (m/s)		Seawater Inlet Temperature (°C)
Total Return Pipe Head Loss (kPa)		Seawater Outlet Temperature (°C)
Static Head (kPa)		Chilled Water Inlet Temperature (°C)
Flow Losses (kPa)		Chilled Water Outlet Temperature (°C)
		SW Flow (kg/s)
eawater Pump Station		FW Flow (kg/s)
Mass Flow (kg/s)	1207	Heat Exchanger Area (m?)
Volumetric Flow (m3/s)	1.17	Heat Transfer Coefficient (kW/m2/°C)
Total Sea Water Pump Head (kPa)		Head Loss including control value (Pa)
Suction Head (m)		L MTD (%C)
Suction Head (kPa)		LMID (C)
Cold Water Pipe (kPa)		
Pressure (kPa)		
Distribution Losses (PPa)		
Heat Exchanger (PDa)		
Patura Dina (LPa)		
Return ripe (Kra)		
Bypass Control valve Loss (KPa)	2.2	
runp Elevation (m)	-2.2	
Seawater pumping power (kW)	267	

1149

995

7.20

0

5.76 5.76

1207 1149



3.1.2. Costs

A detailed cost breakdown was computed for the various sub-systems and installation steps of the SWAC system. The cost estimates were then used to perform a levelized cost analysis, indicating the lifetime costs for the project in units of cost per year per ton of cooling in present value. When comparing two or more scenarios, the one with the lowest levelized cost is generally taken as the most economical.

Table 3-2 summarizes the levelized costs for the SWAC system.

Cost Summary				
System Specifications				
Peak AC Load (Tons)	7,676			
Average AC Load (Tons)	4,732			
Cost of Electricity (\$/kW-h)	0.36			
Levelized Cost (\$/ton/year)				
SWAC Capital Cost	2,235			
SWAC Operating Cost	1,140			
SWAC Periodic Costs	82			
SWAC Total	3,458			
Conventional AC	5,247			

Table 3-2: Summary of Levelized Cost for a SWAC System in Montego Bay

The levelized cost for SWAC was estimated to be \$3458/ton/year. This represents an increase in cost from the \$3386/ton/year previsouly report to CAF in a preliminary analysis due to a decrease from 5029 tons to 4732 tons of cooling load. The decrease in load was caused by a combination of updated loads for the Holiday Inn Sunspree, Sunset Beach Resort and Waterpark, and Halfmoon Resort; and changes to the load curves for the Airport, Freezone, and University. Since the commercial load curve has lower nighttime loads than the resort curve, the annual average cooling consumed by these buildings was reduced. The uniform load applied to the Bogue power station helped offset the reduction.

The levelized cost of SWAC in Montego Bay indicates that it is still a good candidate site for SWAC development. The levelized cost of Conventional AC has been estimated at \$5247/ton/year. Thus, the cost of cooling from seawater is 34% less than that of conventional cooling.

Table 3-3 summarizes the capital costs of the SWAC system.



Table 3-3: Summary of Capital Costs for a SWAC System in Montego Bay (abbreviated for public release)

Capital Costs (k\$)	
Contractor	
P&P Bonds	
CAR Insurance	
General Mob	
Site Specific Mob	(00)
Grand Total	000
Pre Engineering	
Route Survey	
Permitting and Marketing	
Total	1,450
Offshore Seawater Pipes	
Pipe and Fittings	
Pipe Fusion	
Anchors and Stiffeners	
Deployment Preparations	
Deployment	
Shallow Water Anchoring	
Contractor Markup	
Engineering	
Contingency	22.070
Iotai	22,970
Shore Crossing	
Tunnels	
Offshore Trench	
Onshore Trench	
Contractor Markup	
Engineering	
Total	1 554
Total	1,004
Pump Station	
Main Seawater Pumps and Motors	
Main Heat Exchanger	
Chillers TES Taula	
TES Tanks Electrical Service	
New Power Line Installation	
Structure	
Contractor Markup	
Engineering	
Contingency	
Total	9,676
Distribution Natural	
Distribution Network	
Fiftings and Values	
Trench and Install	
Pumps	
Heat Exchangers	
Contractor Markup	
Engineering	
Contingency	
Total	64,081
Tatal SWAC Casital Cast	100.000
Total SWAC Capital Cost	100,330

The capital cost of a Montego Bay SWAC system is dominated by the cost of the onshore distribution system, comprising 64% of the total \$100 million capital cost.

Table 3-4 summarizes the operating costs of the SWAC system. The design uses smaller pipes than the preliminary system previously reported, which reduces capital cost, but increases operating cost. A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



Operating Cost (k\$/year)	
Pump Station	
Maintenance	
Personnel	
Subtotal	68
Pumps	
Electricity	
Maintenance	
Personnel	
Subtotal	4,049
Heat Exch ang ers	
Maintenance	
Personnel	
Subtotal	142
Distribution Network	
Maintenance	
Personnel	
Subtotal	411
Chillers	
Electricity	
Maintenance	
Personnel	
Subtotal	0
TES Tanks	
Maintenance	
Personnel	
Subtotal	33
Offshore Seawater Pipes	
Maintenance	22
Gener al Costs	
Land Use	10
Manager	237
Total Oper ating Cost	4,972

Table 3-4: Summary of Operating Cost of a SWAC System in Montego Bay (abbreviated for public release)

Table 3-5 summarizes the cost of conventional air conditioning in Montego Bay. The operating cost for conventional cooling is 4.4 times higher than that for SWAC, with over \$20 million per year spent on electricity. A simple payback period for the SWAC system can be calculated by dividing the SWAC system capital cost by the savings in operating cost between SWAC and conventional cooling. The simple payback period is 6 years.

Table 3-5: Summary of Conventional Air Conditioning Costs in Montego Bay

Conventional Air Conditioning	
Total Conv. AC Capital Costs (k\$)	12,090
Annual Conventional AC Costs (k\$/year) Electricity	20.892
Water/Sewage	0
Personnel	319
Maintenance Contract	115
Administration and Overhead	38
Total Conv. AC Operating Costs	21,710

3.2. PUERTO PLATA

Two alternative SWAC system designs were considered as part of the SWAC analysis for Puerto Plata: a hybrid SWAC system that uses chillers to augment the seawater cooling, and inclusion of a thermal energy A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN 21



storage system. The hybrid SWAC system was of no economic benefit but inclusion of thermal energy storage did reduce the levelized cost of SWAC cooling. See section 5.2.3 for a discussion of hybrid SWAC in Puerto Plata, and section 5.2.4 for a discussion of thermal energy storage.

3.2.1. Technical Output

Table 3-6 shows the technical details of the modeled system. The schematic shows the temperature, pressure, and water flow throughout the system.

As described in sections 5.1.3 and 5.2.4, the thermal energy storage system will store cold water during offpeak hours, and supply the water back into the system during peak cooling hours. This enables the SWAC cold water intake and district cooling system to be designed for less than peak load.



8	
5	
υy –	
2	
6	
i a l	
S I	

Chilled Water Pump Station		Technical Summary	
Total Flow (kg/s)	724	Seenario	1
Pupper Supply Hand (I-Pa)	124	Peak ACL and (Tons)	6025
Pump Potum Head (IPa)		Average ACLeed (Tons)	4429
Pump Ketum Head (kra)		Average AC Load (10hs)	4430
rump nead (kra)		Inteles Dine	
Head Loss Inrough Heat Exchanger (kPa)		Intake Fipe	1093
Fread Loss Infough Distribution (kPa)	250	Legeth of Intake (m)	-1082
Freshwater pumping power (KW)	300	Length of Intake Pipe (m)	/992
		Outside Diameter of Intake Pipe (m)	1.10
reshwater Distribution System	7.00	Shoreline DR	
Maximum User CW Temperature (°C)	7.20	Intake DR	
Minimum User CW Temperature (°C)		Equivalent DR	
Maximum Pipe Pressure (kPa)		Deep Water Temperature (°C)	
Minimum Pipe Pressure (kPa)		Temperature at Pump Station (°C)	6.37
Maximum User dH (kPa)		Average Flow Velocity (m/s)	
Minimum User dH (kPa)		Total Pipe Suction Head (kPa)	
TES Tank Capacity (Mliters)	11	Static Head (kPa)	
		Flow Losses (kPa)	
Heat Exchangers			
SW dT Across Heat Exchanger (°C)	5.79	Return Pipe	
FW dT Across Heat Exchanger (°C)	5.79	Depth of Return (m)	-50
Seawater Inlet Temperature (°C)		Length of Return Pipe (m)	2188
Seawater Outlet Temperature (°C)		Outside Diameter of Return Pipe (m)	0.80
Chilled Water Inlet Temperature (°C)		Return Pipe DR	
Chilled Water Outlet Temperature (°C)		Max Temperature of Returned Water (°C)	
SW Flow (kg/s)	761	Flow Velocity (m/s)	
FW Flow (kg/s)	724	Total Return Pipe Head Loss (kPa)	
Heat Exchanger Area (m2)		Static Head (kPa)	
Heat Transfer Coefficient (kW/m2/°C)		Flow Losses (kPa)	
Head Loss including control valve (kPa)			
LMTD (°C)		Seawater Pump Station	
		Mass Flow (kg/s)	761
TES Tanks		Volumetric Flow (m3/s)	0.74
Cold Water dT (°C)	0.50	Total Sea Water Pump Head (kPa)	
Warm Water dT (°C)		Suction Head (m)	
Filling Inlet Temperature (°C)		Suction Head (kPa)	
Filling Outlet Temperature (°C)		Cold Water Pipe (kPa)	
Discharging Inlet Temperature (°C)		Pressure (kPa)	
Discharging Outlet Temperature (°C)		Distribution Losses (kPa)	
TES Peak Flow (kg/s)		Heat Exchanger (kPa)	
TES Tank Capacity (MI)	10.67	Return Pipe (kPa)	
TES Tank Utilization (%)		Bypass Control Valve Loss (kPa)	
Peak Flow (kg/s)		Pump Elevation (m)	
		Seawater numning nower (FW)	100
		staward pumping power (kw)	195

A SWAC system in Puerto Plata requires a seawater intake pipe that is 1100 mm in diameter, 8.0 km long, and reaches to 1082 m water depth. This pipe is 200mm smaller and 200m longer than that from the A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



preliminary analysis of Puerto Plata. Use of thermal energy storage reduces the seawater flow rate, but requires colder seawater. The discharge pipe is 800 mm in diameter and 2.2 km long in order to reach 50 m water depth. The seawater pump station must be excavated such that the pumps can be located 3.1 m below sea level.

The cold water intake pipe in Puerto Plata must reach approximately 200 m deeper than those at other sites. This is because the seawater off the north coast of the Dominican Republic is warmer than that elsewhere.

3.2.2. Costs

Table 3-7 summarizes the levelized cost of the SWAC system.

Table 3-7: Summary of Levelized Cost for a SWAC System in Puerto Plata

Cost Summary	
System Specifications	
Peak AC Load (Tons)	6,835
Average AC Load (Tons)	4,438
Cost of Electricity (\$/kW-h)	0.32
Levelized Cost	(k\$/ton/year)
SWAC Capital Cost	1,626
SWAC Operating Cost	748
SWAC Periodic Costs	61
SWAC Total	2,435
Conventional AC	4,691

The levelized cost of SWAC is 48% less than that of conventional cooling at \$2435/ton/year compared to \$4,691/ton/year, respectively. Puerto Plata is a good candidate for SWAC development.

Table 3-8 summarizes the capital cost of the SWAC system. The onshore distribution system is more compact than Montego Bay, accounting for approximately 25% of the \$68.4 million capital cost. The offshore pipe accounts for approximately 50% of the capital cost.



Table 3-8: Summary of Capital Costs for a SWAC System in Puerto Plata (abbreviated for public release)

Capital Costs	
Contractor	(k\$)
P&PBonds	
CAR Insurance	
General Mob	
Site Specific Mob	004
Grand 1 otal	894
Pre Engineering	
Route Survey	
Permitting and Marketing	
Total	1,450
Offshave Segurator Pines	
Pine and Fittings	
Pipe Fusion	
Anchors and Stiffeners	
Deployment Preparations	
Deployment	
Shallow Water Anchoring	
Contractor Markup	
Engineering	
Contingency	
Total	34,724
Shore Crossing	
Tunnels	
Offshore Trench	
Onshore Trench	
Contractor Markup	
Engineering	
Contingency	
Total	1,680
Pump Station	
Main Seawater Pumps and Motors	
Main Heat Exchanger	
Chillers	
TES Tanks	
Electrical Service	
New Power Line Installation	
Structure Contractor Madage	
Contractor Markup	
Engineering	
Total	12 202
1012	12,293
Distribution Network	
Pipe	
Fittings and Valves	
Trench and Install	
Pumps	
Heat Exchangers	
Contractor Markup	
Contingonau	
Total	17 303
	.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Total SWAC Capital Cost	68,430



Table 3-9 summarizes the operating costs of the SWAC system. The majority of the operating cost is electricity for running the seawater and chilled water pumps, comprising 63% of the total operating cost.

Table 3-9: Summary of Operating Cost of a SWAC System in Puerto Plata (abbreviated for public release)

Operating Cost	
Pump Station	(k\$/year)
Maintenance	
Personnel	
Subtotal	68
Pumps	
Electricity	
Maintenance	
Personnel	
Subtotal	1,929
Heat Exchangers	
Maintenance	
Personnel	
Subtotal	114
Distribution Network	
Maintenance	
Personnel	
Subtotal	206
Chillers	
Electricity	
Maintenance	
Personnel	
Subtotal	0
TES Tanks	
Maintenance	
Personnel	
Subtotal	462
Offshore Seawater Pipes	
Maintenance	33
General Costs	
Land Use	10
Manager	237
Total Operating Cost	3,058

Table 3-10 summarizes the cost of conventional air conditioning in Puerto Plata.

Table 3-10: Summary of Conventional Air Conditioning Costs in Puerto Plata

Conventional Air Conditioning	
	(k\$)
Total Conv. AC Capital Costs	10,765
Annual Conventional AC Costs	(k\$/year)
Electricity	17,416
Water/Sewage	0
Personnel	284
Maintenance Contract	103
Administration and Overhead	34
Total Conv. AC Operating Costs	18,145



The operating cost for conventional cooling is 5.9 times higher than that for SWAC with over \$17 million/year for electricity. A simple payback period for the SWAC system can be calculated by dividing the SWAC system capital cost by the savings in operating cost between SWAC and conventional cooling. The simple payback period is 4.5 years.



4. SWAC SYSTEM CONCEPTUAL DESIGN

This chapter describes a much abbreviated conceptual design for the SWAC seawater supply systems at Montego Bay and Puerto Plata. The conceptual design includes additional information on pipeline assembly and installation, pump station consturction and equipment, heat exchangers, and onshore distribution. A more detailed preliminary design was completed by Makai but, due to inclusion of proprietary design details, was omitted for public release of this report.

4.1. OVERVIEW

The SWAC system is comprised of three major sub-systems: a seawater supply system, heat exchangers, and a chilled water distribution loop. Figure 4-1 shows a schematic of the typical SWAC system (without auxiliary chillers or thermal energy storage). The figure shows the cold water intake pipe, pump station, and discharge pipe that comprise the seawater supply system. A freshwater chilled loop supplies water to the buildings. The freshwater loop is continually cooled by passing through a heat exchanger with the cold seawater in a closed loop configuration.

The seawater is drawn up from deep water, typically at a temperature below 7.0°C, through a flexible intake pipeline. Makai designs the SWAC intakes using high density polyethylene pipe, or HDPE. HDPE pipe has several advantages over alternative materials. HDPE is strong, durable, flexible, and cost effective. The HDPE pipe is ballasted using a variety of concrete weight designs, most commonly a variation of concrete anchor clamped tight around the HDPE pipe.

The intake pipe transmits seawater across the shoreline through a buried section of pipe in either a trench or tunnel. Tunnels are typically constructed using micro-tunneling or horizontal directional drilling technologies, depending on the diameter of pipe. For the cost analysis at Montego Bay and Puerto Plata a trenched pipe has been assumed.



*Figure 4-1:*Schematic showing major components of a SWAC system (right) compared to conventional AC (left)



The offshore pipeline, from the buried shorecrossing out to the deep water intake, is installed in two steps; assembly and submergence. During assembly the HDPE pipeline and ballast anchors are staged in a harbor or similarly calm staging site with good access. Segments of HDPE pipe are fused together and anchors are added to the fused pipe sections (see Figure 4-2). Once assembled the longer pipeline segments are flanged together and towed in a single length to the selected alignment, where it is then installed on the seafloor using the controlled submergence process (see Figure 4-3). Once on-site, the controlled submergence occurs in less than a single 24 hour period. Generally, the ballast anchoring is enough to stabilize and resist hydrodynamic motion of the pipe on the seafloor. In nearshore zones, where wave and currents can create large forces on the pipe (typically depth). additional post-deployment <50m

anchors are required which fix the pipe to the seafloor. A variety of embedment and rock-bolt anchoring options exist depending on the



Figure 4-2: HDPE fusion used to join two lengths of pipe during the assembly process.

condition of the seabed. These anchors are typically installed with divers. Based on the anticipated wave heights at Puerto Plata and Montego Bay some additional anchoring in depths less than 50m would be required.

Once installed, the offshore seawater HDPE intake pipe is operated as a suction pipe. Seawater is pumped up through the pipe by pumps located in an onshore sump. The pump station is typically designed using either a wet or dry sump. The pump sumps must be installed deep enough to account for the total head loss in the offshore intake pipe. For Montego Bay and Puerto Plata, a proprietary wet sump station design was assumed. The design uses a combination of novel installation methods and standard construction materials to reduce pump station costs. Figure 4-4 shows an existing pump station located at the Natural Energy Laboratory Figure 4-3: Controlled submergence of an HDPE Authority of Hawai'i (NELHA). This particular pump station is a wet sump design, and services



pipe designed by Makai.

a 1.4m diameter cold water intake pipe, similar to the pump stations that would be appropriate for Montego Bay and Puerto Plata.

Cs



Leaving the pump station, the cold seawater flows through a heat exchanger where heat is transferred from the warmed freshwater flow of the onshore distribution. The heat exchangers must be constructed of marine grade materials to resist corrosion. Entrapment of sealife in the heat exchangers is mitigated by the use of a coarse strainer to filter the seawater prior to the heat exchangers.

The selection of the heat exchanger is critical to the SWAC system and impacts the total cost and operating efficiencies of the SWAC system. For example, a change in the total surface area or performance of the heat exchanger will change the Figure 4-4: Aerial image of the NELHA sump-style amount of cooling provided from the seawater, which in turn may increase the amount of total flow



pump station, located in Kona, HI, USA.

required. A change in total flow will impact the design of the onshore and offshore pipe systems, as well as the pump station. The Makai SWAC model iterates on the design and incorporates these interdependencies to specify the components that provide the lowest overall system cost. The size and type of heat exchangers assumed in this study are those which have provided a lowest estimated levelized cost for the system.

After flowing through the heat exchanger the warmed seawater is then discharged back into the ocean at a depth shallower than the intake. For this preliminary analysis it was assumed a discharge at the depth of 50m. At this depth, the returned seawater would still be several degrees cooler than the relatively shallow ambient waters where it is discharged. The actual depth selected will depend on more detailed local site conditions, environmental regulations, and diffuser dispersion modeling.

The chilled water distribution takes the cold chilled (fresh) water from the SWAC heat exchanger and supplies it to each cooling customer on the network. It also collects the warmed water that has expended its useful cooling capacity and returns it to the heat exchanger for re-cooling. The freshwater distribution is a closed-loop system. It was assumed that all distribution pipes are insulated to prevent heat infiltration from the ground in which the pipes are buried.

4.2. DISTRIBUTION SYSTEM LAYOUT

Makai laid out conceptual distribution piping networks during the preliminary phase of this study. The distribution layouts were reviewed during the analysis described in this report, but no changes were made. Figure 4-5 shows the distribution piping layout in Montego Bay, and Figure 4-6 shows the layout in Puerto Plata.

Cs





Figure 4-5: Conceptual Distribution Piping Layout in Montego Bay

The distribution pipe design assumes that the cold water intake pipe can be brought ashore and connected to a pump station near the airport. This places the pump station near the center of the distribution system. The effect is that the distribution is split into eastern and western portions. This minimizes the size of the distribution pipes that must be installed; if the pump station were located at the east end of the distribution system (near the Holiday Inn Sunspree), then the distribution piping would have to be large enough to serve the entire network. With a centrally located pump station, the distribution piping that goes east is sized to meet the eastern load, while the piping that goes west is sized to meet the western load – no pipes are required to carry the full SWAC flow outside the pump station.

The Puerto Plata distribution system is extremely compact; most of the potential customers lie within the Playa Dorada complex. The pump station was located in an open space near the shore. It could be located anywhere on the shoreline of the Playa Dorada complex with little impact on the distribution system design. The analysis was repeated to determine if the Be Live Grand Marien and Iberostar resorts should be included in the SWAC system. Including them reduces the total levelized cost of the system, which means that the revenue obtained is enough to pay for the additional distribution piping required to reach them.

Ċs





Figure 4-6: Conceptual Distribution Piping Layout in Puerto Plata

The distribution designs and pump station locations shown above are subject to revision during detailed design. Land ownership, existing rights of way, and environmental requirements could make installation of a pump station or distribution piping in certain areas impossible. It will be necessary to engage with local

government and landowners to determine where the pipes and pump stations can be located prior to the beginning of final design.

Makai recommends use of HDPE distribution pipes, though cast iron and steel pipes are an option. The fact that HDPE pipes are heat-fused into long continuous lengths minimizes the change for chilled water leakage. Their inherent flexibility is also a benefit during seismic events – they are able to withstand more deflection (without failure) than metallic pipes. Finally, HDPE pipes require less insulation because the plastic is inherently less conductive than metal. The disadvantage of HDPE is that a fusion machine is required to assemble the pipe. Fusion



Figure 4-7: Distribution Pipe Installed under a Roadway



machines are larger than welding equipment, and require more specialized operators. Rigorous selection of the distribution piping material is part of the final design process.

Distribution pipes are typically installed in a trench below the surface of the ground. Supply and return pipes are laid parallel in the same trench. In urban environments, it is typically necessary to install the distribution pipes underneath roadways.

The overlying road was removed and the trench opened. After the pipes are installed the trench will be backfilled and the road repaved. To minimize the cost for trenching, the pipes should be installed as shallow as possible. The minimum cover varies depending on the street surface construction, the traffic load, and local construction codes, but a minimum of 2 feet is often acceptable. Figure 4-8 shows a schematic of a completely installed pair of distribution pipes, including refinishing of the original surface.



Figure 4-8: Typical closed loop trench connection

The space underneath roads is a common location for installation of utilities, and there may be other pipes for water, sewer, natural gas, or electrical conduits already in place. The SWAC distribution pipe installation process will need to take these other utilities into account. It is likely that the pipes will need to be installed without interrupting the service of the existing utilities. This is a common requirement, and pipe installation contractors are familiar with the techniques required to work around existing pipes. Figure 4-9 shows the installation of distribution pipes around existing utilities.





Figure 4-9: Installation of Distribution Pipe around Existing Utilities

An alternative to the open trench approach shown above is horizontal directional drilling. Directional drilling pushes pipe into the ground without the need to dig up the entire pipe path. The benefit is that current use of the space above the pipe path (e.g. – road traffic) may not be impeded during construction. Drilling requires detailed knowledge of the precise locations of existing utilities, as well as the geological characteristics of the area. The final selection of distribution pipe installation typically depends on local environmental requirements or government requirements that traffic not be impeded, and is usually determined during final design.


5. SENSITIVITY ANALYSIS

Makai used the SWAC model to perform sensitivity studies on the effect of electrical rate, cooling load, hybrid SWAC, and thermal energy storage tank (TES) capacity on the levelized cost of SWAC systems in Montego Bay and Puerto Plata. The electrical rate and cooling load sensitivity studies provide insight into how those elements impact the economic viability of the SWAC system. The hybrid SWAC and TES capacity studies investigate the effects of alternative design concepts on levelized cost.

The sections below include a variety of technical and cost output tables from the SWAC model. In order to present the results of each sensitivity study within a single table, some parts of the output have been omitted compared to the tables presented in sections 3.1 and 3.2. Those portions that have been omitted are unchanged by the sensitivity study, and therefore are not needed to understand the results. Some tabulated data has also been abbreivated for the public release of this report.

5.1. MONTEGO BAY

5.1.1. Electrical Cost

A sensitivity study of electrical rate reveals how changes in the cost of electricity impact the relative economics of SWAC and conventional cooling. The economic module of the SWAC model was exercised for a variety of electrical rates centered about the current cost of \$0.36/kW-hr. Figure 5-1 shows the resulting levelized cost (\$/ton/year) of SWAC and conventional AC as a function of varying electrical rates (\$/kW-hr).



Figure 5-1: Comparison of the Effect of Electrical Rate on SWAC (blue) and Conventional AC (red) in Montego Bay in levelized cost units of \$/ton/year.

The levelized cost of conventional air conditioning is much more sensitive to electrical rate than is SWAC, as seen by the steeper slope on the red area than the blue area in Figure 5-1. This is due to the fact that the A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN 35



majority of the cost of SWAC is in capital – only a small portion of the lifecycle cost is due to the electrical cost to operate the pumps. In contrast, the majority of the lifecycle cost of conventional air conditioning goes to electricity to operate the chillers. The above relationships mean that SWAC is favored when electrical rates are high, and conventional cooling is favored when electrical rates are low. The cost of electricity in Montego Bay is high enough the levelized cost of SWAC does not exceed that of conventional cooling within the bounds of the sensitivity study.

Table 5-1 shows the detailed economic output of the sensitivity study.

Cooling capital cost is unaffected by electrical rate, and the SWAC operating cost rises more slowly than the conventional cooling operating cost. The maximum electrical rate considered (\$0.45/kW-hr) represents an 80% increase in electrical cost over the minimum rate (\$0.25/kW-hr). SWAC operating costs rise 59% over this range, while conventional cooling costs rise 76%. The magnitude of the difference is significant, with SWAC operating costs rising by \$2.2 million while conventional cooling cost rises by \$11.6 million. The simple payback period for SWAC varies from 8.7 years at the minimum electrical rate to 4.8 years at the maximum rate.

5.1.1. Cooling Load

SWAC system economics are sensitive to total system size. Larger SWAC systems are more economically viable than smaller SWAC systems. The fact that the cooling loads in Montego Bay are mostly estimates, and the fact that the cooling equipment in use is unknown for most potential customers, means that there is a large uncertainty in the actual cooling load available for connection to SWAC. To determine the impact of the uncertainty on the SWAC viability, a sensitivity study on load factor was carried out. Load factor is a ratio between actual cooling load and expected cooling load. A load factor of 0.5 means that all cooling loads connected to the system are 50% of the expected values. Varying load factor allows the SWAC model to investigate a variety of system sizes. The extent of the distribution system is constant for each system size, but the diameter of distribution and offshore pipes used is varied as the chilled water flow rate varies. The onshore pipe diameters are not optimized for each load factor, so the levelized cost at a load factor of 1.0 is slightly higher than that shown in

Table 3-2.



Cost Summary System Specifications Parameter: Electrical Rate (\$/kWh) 0.25 0.26 0.27 0.28 0.29 0.30 0.31 0.32 0.33 0.34 0.35 0.36 0.37 0.38 0.39 0.40 0.41 0.42 0.43 0.44 0.45 Peak AC Load (Tons) 7,676 Average AC Load (Tons) 4.732 4.732 4.732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4,732 4.732 Cost of Electricity (\$/kW-h) 0.25 0.26 0.27 0.28 0.29 0.30 0.31 0.32 0.33 0.34 0.35 0.36 0.37 0.38 0.39 0.40 0.41 0.42 0.43 0.44 0.45 Levelized Cost SWAC Capital Cost 2,235 2.235 2,235 2,235 2.235 2,235 2,235 2.235 2,235 2,235 2.235 2,235 2,235 2.235 2.235 2,235 2.235 2.235 2.235 2,235 2.235 SWAC Operating Cost 861 886 912 937 962 988 1.013 1.038 1.064 1.089 1.114 1.140 1,165 1.191 1,216 1,241 1.267 1.292 1.317 1,343 1.368 SWAC Periodic Costs 82 82 82 82 - 82 82 82 82 82 82 82 82 82 82 82 82 82 82 82 82 82 SWAC Total 3,179 3,204 3,229 3,255 3,280 3,305 3,331 3,356 3,381 3,407 3,432 3,458 3,483 3,508 3,534 3,559 3,584 3,610 3,635 3,660 3,686 Conventional AC 3.783 3,916 4.049 4.182 4.315 4,448 4.581 4,714 4.848 4.981 5,114 5.247 5.380 5.513 5.646 5,779 5.912 6.045 6,178 6.311 6.444 Capital Costs Total SWAC Capital Cost 100,330 100,300 **Operating Cost** Pumps Electricity 2,765 2,875 2,986 3,096 3,207 3,318 3,428 3,539 3,649 3,760 3,871 3,981 4,092 4,202 4,313 4,424 4,534 4,645 4,755 4,866 4,976 Maintenance 65 Personnel 65 65 6 65 65 65 65 6 65 65 65 65 65 65 65 65 65 65 65 65 4,602 2,832 2,943 3,053 3,164 3,275 3,385 3,496 3,606 3,717 3,828 3,938 4,049 4,159 4,270 4,381 4,491 4,712 4,823 4,933 5,044 Subtotal **Total Operating Cost** 3.755 3.866 3.976 4.087 4.198 4.308 4,419 4.529 4.640 4,751 4.861 4,972 5.082 5.193 5.304 5.414 5.525 5.635 5.746 5.857 5.967 **Conventional Air Conditioning** Total Conv. AC Capital Costs 12,090 Annual Conventional AC Costs 14,508 15,089 16,249 17,990 18,571 19,731 22,053 24,374 24,954 15,669 16,830 17,410 19,151 20,312 20,892 21,472 22,633 23,213 23,794 25,535 26,115 Electricity Water/Sewage 319 Personnel Maintenance Contract 115 Administration and Overhead 38 38 38 38 38 38 38 -38 - 38 38 38 38 38 -38 38 38 38 32 38 38 38 15,907 16,487 17,648 19,389 19,969 20,550 21,130 22,291 26,933 15,327 17,068 18,228 18,809 21,710 22,871 23,451 25,192 Total Conv. AC Operating Costs 24,032 24,612 25,773 26,353

Table 5-1: Cost Output of Montego Bay Electrical Rate Sensitivity Study

Figure 5-2 (following page) shows the impact of load factor on SWAC levelized cost





Figure 5-2: Comparison of the Effect of Load Factor on SWAC and Conventional AC in Montego Bay

A SWAC system in Montego Bay is slightly more sensitive to load reduction than load increase. This is visible in that the slope of the blue area in Figure 5-2 is generally steeper on the left side of the plot than the right. The unevenness in slope is due to the fact that the offshore pipe costs change in discrete increments (pipe diameters). SWAC is cost competitive with conventional cooling over the entire range of the sensitivity study, which indicates that uncertainty in total cooling load does not pose a large risk to SWAC system economic viability. Table 5-2 shows abbreviated cost output from the sensitivity study.



Table 5-2: Cost Output of Montego Bay Load Factor Sensitivit	ty Study (abbreviated for public release)
--	---

Cost Summary											
System Specifications											
Parameter: Load Factor	0.50	0.60	0.70	0.80	0.90	1.00	1.10	1.20	1.30	1.40	1.50
Peak AC Load (Tons)	3,838	4,606	5,373	6,141	6,908	7,676	8,444	9,211	9,979	10,746	11,514
Average AC Load (Tons)	2,366	2,839	3,312	3,786	4,259	4,732	5,205	5,678	6,152	6,625	7,098
Cost of Electricity (\$/kW-h)	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36
Levelized Cost											
SWAC Capital Cost	3,009	2,845	2,745	2,564	2,439	2,375	2,332	2,219	2,148	2,145	2,039
SWAC Operating Cost	1,486	1,310	1,284	1,212	1,201	1,086	1,058	1,004	1,030	1,002	970
SWAC Periodic Costs	149	126	111	99	90	82	75	70	66	62	59
SWAC Total	4,645	4,281	4,140	3,875	3,730	3,542	3,466	3,293	3,244	3,210	3,068
Conventional AC	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247
Capital Costs											
Offshore Seawater Pipes Total	15,684	18,216	21,686	21,884	22,779	22,971	24,099	24,292	24,391	25,516	25,683
Pump Station Total	6,517	6,813	7,323	8,275	8,753	9,672	10,147	11,060	12,023	11,923	12,596
Distribution Network Total	41,934	48,121	53,674	58,358	63,377	70,331	77,286	80,551	85,298	93,691	95,316
Total SWAC Capital Cost	67,530	76,600	86,250	92,080	98,510	106,580	115,150	119,520	125,330	134,790	137,260
Operating Cost											
Subtotal	2,460	2,611	3,066	3,346	3,802	3,787	4,087	4,241	4,799	5,033	5,248
Heat Exchangers Subtotal	104	112	120	127	135	142	150	157	165	172	180
Total Operating Cost	3,241	3,429	3,919	4,228	4,714	4,737	5,076	5,253	5,840	6,119	6,349
Conventional Air Conditioning											
Total Conv. AC Capital Costs Total Conv. AC Operating Costs	6,045 10,855	7,254 13,026	8,463 15,197	9,672 17,368	10,881 19,539	12,090 21,710	13,299 23,881	14,508 26,052	15,717 28,223	16,926 30,394	18,135 32,565

The levelized cost of conventional cooling is unaffected by changes in load factor. This is because both the capital and operating costs of conventional cooling scale linearly with cooling load. SWAC, however, exhibits an economy of scale; both capital and operating costs rise more slowly with increasing load. The maximum cooling load (150% of the expected load) represents a 300% increase over the minimum cooling load (50% of the expected load). Over this range, SWAC capital costs increase by 203%, and SWAC operating costs increase by 196%. Conventional cooling capital cost and operating cost increases by 300%. The simple payback period varies from 8.9 years at the minimum load to 5.2 years at the maximum load.

Table 5-3 shows the technical differences in SWAC system design for the different load factors.



Technical Summary											
Parameter: Load Factor	0.5	0.6	0.7	0.8	0.9	1	1.1	1.2	1.3	1.4	1.5
Peak AC Load (Tons)	3838	4605.6	5373.2	6140.8	6908.4	7676	8443.6	9211.2	9978.8	10746.4	11514
Average AC Load (Tons)	2366	2839	3312	3786	4259	4732	5205	5678	6152	6625	7098
Intake Pipe											
Depth of Intake (m)	-898	-893	-890	-884	-883	-880	-879	-876	-874	-874	-872
Length of Intake Pipe (m)	4550	4530	4516	4492	4486	4473	4469	4460	4450	4449	4443
Outside Diameter of Intake Pipe (m)	0.90	1.00	1.10	1.10	1.20	1.20	1.30	1.30	1.30	1.40	1.40
Deep Water Temperature (°C)	5.90	5.97	6.03	6.11	6.14	6.19	6.20	6.23	6.27	6.27	6.30
Return Pipe											
Outside Diameter of Return Pipe (m)	0.71	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Max Temperature of Returned Water (°C)	12.36	12.33	12.31	12.29	12.28	12.27	12.26	12.25	12.25	12.25	12.24
Seawater Pump Station											
Mass Flow (kg/s)	603	724	845	965	1086	1207	1328	1448	1569	1690	1810
Seawater pumping power (kW)	141	147	174	202	234	265	300	335	374	414	458
Chilled Water Pump Station											
Total Flow (kg/s)	574	689	804	919	1034	1149	1263	1378	1493	1608	1723
Freshwater pumping power (kW)	617	660	777	837	950	914	974	987	1125	1160	1184
Heat Exchangers											
SW dT Across Heat Exchanger (°C)	5.86	5.83	5.81	5.80	5.78	5.77	5.77	5.76	5.75	5.75	5.74
SW Flow (kg/s)	603	724	845	965	1086	1207	1328	1448	1569	1690	1810
FW Flow (kg/s)	574	689	804	919	1034	1149	1263	1378	1493	1608	1723

Table 5-3: Technical Output of Montego Bay Load Factor Sensitivity Study (abbreviated for public release)

The offshore pipe diameters change by 0.5m diameter over the range of cooling loads and the intake pipe varies from 900 mm diameter to 1400 mm diameter, while the return pipe varies between 710 mm and 1000 mm. The intake pipe must also go deeper at reduced load. This is to account for the fact that pipes with lower flow rates are more subject to warming than pipes with higher flow rates. The seawater pump energy, chilled water pump energy, and heat exchanger area also scale with the cooling load. Low load factors require less water flow and less heat transfer area than high load factors.

5.1.2. Hybrid SWAC

Hybrid SWAC is a term that applies to SWAC systems that use a chiller to augment seawater cooling. One of the major design factors that drive offshore intake pipe cost is the temperature of water required. In "pure" SWAC (which is the type of system discussed in the rest of this report), the intake pipe must acquire water cold enough to supply all cooling customers with adequately cold chilled water after all heat gains in pipes have been accounted for. In hybrid SWAC, seawater that is warmer than required is obtained. This results in chilled water coming out of the heat exchanger that is too warm to meet cooling customer temperature requirements. An auxiliary chiller downstream of the heat exchanger is used to drop the chilled water to the required temperature. In doing so, the chiller is absorbing some of the cooling load coming from the distribution system. Figure 5-3 shows a schematic of pure SWAC, and Figure 5-4 shows a schematic of hybrid SWAC.





Figure 5-3: Schematic of Pure SWAC



Figure 5-4: Schematic of Hybrid SWAC

The advantage of a hybrid SWAC system is that the offshore pipe can be made shorter. The disadvantage is that the chiller has a large operating cost that erodes the advantage of SWAC over conventional cooling. A hybrid system can be cost effective when it is too expensive to acquire adequately cold water, but "cool" water that can absorb some (but not all) of the cooling load is available at reduced cost. In such a case, the capital cost savings from the shortened cold water pipe outweighs the increased operating cost caused by the auxiliary chiller.

Makai investigated the benefit of hybrid SWAC by performing a sensitivity study on auxiliary chiller temperature drop. In a hybrid SWAC system, the amount of cooling load absorbed by the chiller (and the amount by which the intake pipe can be shortened) is controlled by the chiller temperature drop. A high temperature drop results in a short intake pipe, but a high operating cost because the chiller must absorb



more of the cooling load. A low temperature drop requires a longer intake pipe, but has a lower operating cost. The sensitivity study can determine whether hybrid SWAC is cost effective, as well as the temperature drop at which a cost effective system should operate. Figure 5-5 shows the impact of hybrid SWAC on the Montego Bay system.



Figure 5-5: The Effect of Hybrid SWAC on Levelized Cost in Montego Bay

Hybrid SWAC is not cost effective in Montego Bay – the minimum levelized cost on the curve is where the temperature drop is zero (pure SWAC). This conclusion is sensitive to the assumed bathymetric profile. Hybrid SWAC is typically cost effective when there is a long flat section of seabed just inshore of the depth at which a pure SWAC intake would be placed. Since no detailed bathymetry offshore of Montego Bay is available, it is unknown whether such a plateau exists. The assumed bathymetric profile assumes a steady increase in depth, so results could vary once more detailed bathymetry data is obtained. Table 5-4 shows the detailed cost output of the hybrid SWAC sensitivity study.



-2.00	-1.75	-1.50	-1.25	-1.00	-0.75	-0.50	-0.25	0.00
7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676
4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732
0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36
2,463	2,450	2,436	2,426	2,426	2,413	2,400	2,387	2,372
3,270	3,020	2,769	2,519	2,269	2,018	1,768	1,517	1,087
84	84	84	84	84	84	84	84	82
5,817	5,554	5,290	5,029	4,779	4,515	4,251	3,988	3,541
5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247
21 592	21 655	21 722	21.020	22 595	22 672	22 750	22.046	22.071
21,382	21,033	21,732	21,959	22,383	22,075	22,139	22,840	22,971
15,078	14,417	13,725	13,033	12,384	11,694	11,030	10,363	9,656
70,314	70,314	70,314	70,314	70,314	70,314	70,314	70,314	70,244
110 500	100.050	100 250	100.050	100.000	100 000	105 510	105 120	106 450
110,560	109,970	109,350	108,870	108,890	108,280	107,710	107,130	106,470
4,576	4,576	4,576	4,576	4,576	4,576	4,575	4,575	3,793
150	149	148	147	146	145	144	143	142
150	149	140	147	140	145	144	145	142
14,263	13,172	12,080	10,988	9,896	8,804	7,711	6,619	4,743
12 000	12 000	12 090	12 000	12 000	12 000	12 090	12 090	12 000
21,710	21,710	21,710	21.710	21,710	21,710	21,710	21,710	21.710
	-2.00 7,676 4,732 0.36 2,463 3,270 84 5,817 5,247 21,582 15,078 70,314 110,560 4,576 150 14,263 12,090 21,710	-2.00 -1.75 7,676 7,676 4,732 4,732 0.36 0.36 2,463 2,450 3,270 3,020 84 84 5,817 5,554 5,247 5,247 21,582 21,655 15,078 14,417 70,314 70,314 110,560 109,970 4,576 4,576 150 149 14,263 13,172 12,090 12,090 21,090 21,090	-2.00 -1.75 -1.50 7,676 7,676 7,676 4,732 4,732 4,732 0.36 0.36 0.36 2,463 2,450 2,436 3,270 3,020 2,769 84 84 84 5,817 5,554 5,290 5,247 5,247 5,247 21,582 21,655 21,732 15,078 14,417 13,725 70,314 70,314 70,314 109,970 109,350 109,350 4,576 4,576 4,576 150 149 148 14,263 13,172 12,080 12,090 12,090 12,090 21,710 21,710 21,710	-2.00 -1.75 -1.50 -1.25 7,676 7,676 7,676 7,676 4,732 4,732 4,732 4,732 0.36 0.36 0.36 0.36 0.36 2,463 2,450 2,436 2,426 3,270 3,020 2,769 2,519 84 84 84 84 5,817 5,554 5,290 5,247 5,247 5,247 5,247 5,247 21,582 21,655 21,732 21,939 15,078 14,417 13,725 13,033 70,314 70,314 70,314 70,314 10,560 109,970 109,350 108,870 4,576 4,576 4,576 4,576 4,576 4,576 4,576 4,576 150 149 148 147 14,263 13,172 12,080 10,988 12,090 12,090 12,090 12,090	-2.00 -1.75 -1.50 -1.25 -1.00 7,676 7,676 7,676 7,676 7,676 4,732 4,732 4,732 4,732 4,732 0.36 0.36 0.36 0.36 0.36 0.36 2,463 2,450 2,436 2,426 2,426 3,270 3,020 2,769 2,519 2,269 84 84 84 84 84 5,817 5,554 5,290 5,029 4,779 5,247 5,247 5,247 5,247 5,247 21,582 21,655 21,732 21,939 22,585 15,078 14,417 13,725 13,033 12,384 70,314 70,314 70,314 70,314 70,314 70,314 70,314 70,314 70,314 70,314 100,970 109,350 108,870 108,890 4,576 4,576 4,576 4,576 4,576 4,576<	-2.00 -1.75 -1.50 -1.25 -1.00 -0.75 $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $4,732$ $4,732$ $4,732$ $4,732$ $4,732$ 0.36 0.36 0.36 0.36 0.36 0.36 $2,463$ $2,450$ $2,436$ $2,426$ $2,426$ $2,413$ $3,270$ $3,020$ $2,769$ $2,519$ $2,269$ $2,018$ 84 84 84 84 84 84 $5,817$ $5,554$ $5,290$ $5,029$ $4,779$ $4,515$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $21,582$ $21,655$ $21,732$ $21,939$ $22,585$ $22,673$ $15,078$ $14,417$ $13,725$ $13,033$ $12,384$ $11,694$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $4,576$ </td <td>-2.00$-1.75$$-1.50$$-1.25$$-1.00$$-0.75$$-0.50$$7,676$$7,676$$7,676$$7,676$$7,676$$7,676$$7,676$$7,676$$4,732$$4,732$$4,732$$4,732$$4,732$$4,732$$4,732$$0.36$$0.36$$0.36$$0.36$$0.36$$0.36$$0.36$$2,463$$2,450$$2,436$$2,426$$2,426$$2,413$$2,400$$3,270$$3,020$$2,769$$2,519$$2,269$$2,018$$1,768$$84$$84$$84$$84$$84$$84$$84$$5,817$$5,554$$5,247$$5,247$$5,247$$5,247$$5,247$$5,247$$5,247$$5,247$$5,247$$5,247$$21,582$$21,655$$21,732$$21,939$$22,585$$22,673$$22,759$$15,078$$14,417$$13,725$$13,033$$12,384$$11,694$$11,030$$70,314$$70,314$$70,314$$70,314$$70,314$$70,314$$70,314$$10,560$$109,970$$109,350$$108,870$$108,890$$108,280$$107,710$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$4,576$$15,078$$13,172$$12,080$$10,988$$9,896$$8,804$$7,711$$12,090$$12,090$$12,090$$12,090$$12,070$$12,070$<</td> <td>-2.00 -1.75 -1.50 -1.25 -1.00 -0.75 -0.50 -0.25 7,676 7,6</td>	-2.00 -1.75 -1.50 -1.25 -1.00 -0.75 -0.50 $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $7,676$ $4,732$ $4,732$ $4,732$ $4,732$ $4,732$ $4,732$ $4,732$ 0.36 0.36 0.36 0.36 0.36 0.36 0.36 $2,463$ $2,450$ $2,436$ $2,426$ $2,426$ $2,413$ $2,400$ $3,270$ $3,020$ $2,769$ $2,519$ $2,269$ $2,018$ $1,768$ 84 84 84 84 84 84 84 $5,817$ $5,554$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $5,247$ $21,582$ $21,655$ $21,732$ $21,939$ $22,585$ $22,673$ $22,759$ $15,078$ $14,417$ $13,725$ $13,033$ $12,384$ $11,694$ $11,030$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $70,314$ $10,560$ $109,970$ $109,350$ $108,870$ $108,890$ $108,280$ $107,710$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $4,576$ $15,078$ $13,172$ $12,080$ $10,988$ $9,896$ $8,804$ $7,711$ $12,090$ $12,090$ $12,090$ $12,090$ $12,070$ $12,070$ <	-2.00 -1.75 -1.50 -1.25 -1.00 -0.75 -0.50 -0.25 7,676 7,6

Table 5-4: Cost	Output of	Montego	Bay Hybrid	SWAC	Sensitivity	Study
------------------------	-----------	---------	------------	------	-------------	-------

As auxiliary chiller temperature change becomes more negative (increased chiller temperature drop), the cost of the offshore pipes decreases, and the cost of the pump station increases. The decrease in offshore pipe cost is due to decreasing intake depth, while the increase in pump station cost is due to an increase in the cost to purchase auxiliary chillers. The decrease in pipe cost is smaller than the increase in chiller cost; it is more expensive to purchase chillers than it is to purchase a longer intake pipe. The incremental cost of intake pipe is the factor that is sensitive to seabed slope. The steady slope in the assumed bathymetric profile is the root cause of the small changes in offshore pipe cost. The SWAC operating cost rises by three fold as chiller temperature change becomes more negative. This represents the increasing amount of electricity consumed by the chiller.

Table 5-5 shows the technical differences in SWAC system design due at the various chiller temperature drops considered.



Technical Summary									
Parameter: Chiller DeltaT (°C)	-2	-1.75	-1.5	-1.25	-1	-0.75	-0.5	-0.25	0
Peak AC Load (Tons)	7676	7676	7676	7676	7676	7676	7676	7676	7676
Average AC Load (Tons)	4732	4732	4732	4732	4732	4732	4732	4732	4732
Intake Pipe									
Depth of Intake (m)	-752	-768	-783	-799	-815	-831	-847	-863	-880
Length of Intake Pipe (m)	3940	4005	4070	4136	4203	4271	4338	4405	4473
Outside Diameter of Intake Pipe (m)	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20
Deep Water Temperature (°C)	8.21	7.95	7.70	7.45	7.20	6.94	6.69	6.44	6.19
Return Pipe									
Outside Diameter of Return Pipe (m)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Max Temperature of Returned Water (°C)	14.83	14.51	14.19	13.87	13.55	13.23	12.91	12.59	12.27
Seawater Pump Station									
Mass Flow (kg/s)	1206	1206	1206	1206	1206	1206	1207	1207	1207
Seawater pumping power (kW)	267	267	267	267	267	267	267	267	267
Chilled Water Pump Station									
Total Flow (kg/s)	1149	1149	1149	1149	1149	1149	1149	1149	1149
Freshwater pumping power (kW)	1162	1162	1162	1162	1162	1162	1162	1162	914
Heat Exchangers									
SW dT Across Heat Exchanger (°C)	6.35	6.28	6.21	6.13	6.06	5.99	5.92	5.85	5.77
SW Flow (kg/s)	1206	1206	1206	1206	1206	1206	1207	1207	1207
FW Flow (kg/s)	1149	1149	1149	1149	1149	1149	1149	1149	1149

Table 5-5: Technical Output of Montego Bay Hybrid SWAC Sensitivity Study

The cold water intake depth decreases as chiller temperature change becomes more negative (larger temperature drop). However, the change in length is not enough to allow a reduction in intake pipe diameter. This is another factor that minimizes the savings from hybrid SWAC at Montego Bay.

5.1.3. Thermal Energy Storage

Thermal energy storage (TES) is a method of evening out daily variations in cooling load. In a SWAC system without TES, the seawater system must be sized to meet the peak cooling loads. Therefore, the system is oversized the majority of the time. A TES system stores cooling energy during low-load periods and supplements the seawater system during high-load periods. This allows a smaller and less expensive seawater system while still meeting peak loads.

There are a variety of TES systems available – the SWAC model assumes cold water storage. In a cold water storage system, a tank is filled with chilled water during periods of low cooling load (e.g. – at night). During the day, the stored chilled water is discharged into the chilled water supply system to augment the seawater system. Figure 5-6 illustrates the chilled water storage concept.





Figure 5-6: Diagram of Chilled Water Storage Operation

During the blue-shaded times, chilled water from the SWAC heat exchanger is diverted away from the distribution system and into the TES tank. The reduced chilled water flow to the distribution system is acceptable because the cooling load requirement is less than that supplied by the seawater system. During the red-shaded times, all chilled water from the SWAC heat exchanger is sent to the distribution system, but it is not enough to meet the full cooling load. Chilled water stored in the TES tank is added to that coming from the heat exchanger to meet the system's cooling needs.

A TES tank can be sized to completely even out a SWAC system's daily variation. In such cases, the SWAC system is sized to meet the average load and the TES system supplies all above-average loads. Alternatively, the tank could also be sized to handle only the highest loads, while the SWAC system is sized to handle some loads larger than average, but not the highest loads. Makai used a sensitivity study to analyze TES in order to determine both its overall economic viability and the optimum TES tank size. Figure 5-7 shows the results of the Montego Bay TES system sensitivity study.





Figure 5-7: The Effect of TES Tank Capacity on SWAC Levelized Cost in Montego Bay

Thermal energy storage is not economically viable in Montego Bay; the minimum levelized cost on the curve is at a tank capacity of zero (no TES). If a tank were used anyway, the optimum tank size is 4 Mliters. Table 5-6 shows the detailed cost output of the sensitivity study.

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



Cost Summary												
System Specifications												
Parameter: TES Tank Capacity (Ml)	0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00
Peak AC Load (Tons)	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676	7,676
Average AC Load (Tons)	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732	4,732
Cost of Electricity (\$/kW-h)	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36
Levelized Cost												
SWAC Capital Cost	2,375	2,397	2,398	2,400	2,389	2,397	2,399	2,400	2,403	2,406	2,410	2,413
SWAC Operating Cost	1,086	1,098	1,093	1,090	1,088	1,089	1,089	1,088	1,088	1,088	1,089	1,089
SWAC Periodic Costs	82	83	82	82	82	82	82	82	81	81	81	81
SWAC Total	3,542	3,577	3,573	3,573	3,559	3,568	3,569	3,571	3,572	3,576	3,580	3,583
Conventional AC	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247	5,247
Capital Costs												
Offshore Seawater Pipes	22.071	22 805	22 822	22 782	21.086	21.061	21.042	21.060	21 022	21.004	21 880	21.855
Total	22,971	22,093	22,032	22,783	21,960	21,901	21,942	21,900	21,922	21,904	21,000	21,655
Pump Station												
Total	9,672	10,688	10,770	10,920	11,225	11,703	11,812	11,942	12,077	12,260	12,429	12,598
Distribution Network												
Total	70,331	70,376	70,415	70,431	70,450	70,337	70,336	70,275	70,274	70,274	70,290	70,289
	106 500	105 500	105 (20	105 5 40	105 000	105 500	105 (50	105 5 40	105040	100.000	100 1 (0	100 210
Total SWAC Capital Cost	106,580	107,560	107,620	107,740	107,220	107,560	107,650	107,740	107,840	108,000	108,160	108,310
Operating Cost												
Pumps												
Subtotal	3,787	3,715	3,661	3,619	3,580	3,555	3,522	3,492	3,462	3,435	3,408	3,383
Subtotal	142	139	136	135	133	131	129	128	126	125	123	122
Bubtotal	112	107	150	155	155	151	12)	120	120	125	125	122
Total Operating Cost	4,737	4,789	4,766	4,756	4,747	4,752	4,748	4,748	4,746	4,747	4,748	4,749
Conventional AIF Conditioning												
Total Conv. AC Capital Costs	12.090	12.090	12.090	12.090	12.090	12.090	12.090	12.090	12.090	12.090	12.090	12.090
Total Conv. AC Operating Costs	21,710	21,710	21,710	21,710	21,710	21,710	21,710	21,710	21,710	21,710	21,710	21,710

Table 5-6: Cost Output of Montego Bay TES Tank Sensitivity Study

The cost of the offshore pipe decreases as tank capacity increases. This is driven by the reduction in required seawater flow rate. Reduced flow rate allows use of thinner pipe wall and/or reduced pipe diameter, both of which reduce cost. The total capital cost of the SWAC system increases as tank size increases, which means the cost of the TES tank exceeds the savings from the cold water pipe. The cost for electricity to run the seawater pumps decreases as tank capacity increases, but the maintenance cost for the tank almost completely offsets the savings.

Table 5-7 shows the technical SWAC design differences at the different tank sizes considered.

Technical Summary												
Parameter: TES Tank Capacity (Ml)	0	1	2	3	4	5	6	7	8	9	10	11
Peak AC Load (Tons)	7676	7676	7676	7676	7676	7676	7676	7676	7676	7676	7676	7676
Average AC Load (Tons)	4732	4732	4732	4732	4732	4732	4732	4732	4732	4732	4732	4732
Intake Pipe												
Depth of Intake (m)	-880	-884	-888	-890	-891	-893	-895	-898	-900	-905	-911	-917
Length of Intake Pipe (m)	4473	4492	4507	4518	4519	4528	4538	4548	4558	4580	4603	4627
Outside Diameter of Intake Pipe (m)	1.20	1.20	1.20	1.20	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10
Deep Water Temperature (°C)	6.19	6.11	6.06	6.02	6.01	5.98	5.94	5.91	5.87	5.84	5.80	5.77
Return Pipe												
Outside Diameter of Return Pipe (m)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Max Temperature of Returned Water (°C)	12.27	12.28	12.28	12.28	12.29	12.29	12.30	12.30	12.30	12.31	12.31	12.32
Seawater Pump Station												
Mass Flow (kg/s)	1207	1144	1099	1064	1031	1001	972	943	916	892	868	844
Seawater pumping power (kW)	265	249	237	228	219	211	204	198	191	185	179	174
Chilled Water Pump Station												
Total Flow (kg/s)	1149	1089	1046	1013	981	953	925	898	872	849	826	804
Freshwater pumping power (kW)	914	865	831	803	778	758	736	713	692	674	655	637
Heat Exchangers												
SW dT Across Heat Exchanger (°C)	5.77	5.83	5.86	5.89	5.92	5.94	5.97	5.99	6.02	6.03	6.05	6.07
SW Flow (kg/s)	1207	1144	1099	1064	1031	1001	972	943	916	892	868	844
FW Flow (kg/s)	1149	1089	1046	1013	981	953	925	898	872	849	826	804

Table 5-7: Technical Output of Montego Bay TES Tank Sensitivity Study

Seawater flow rate decreases as tank size increases. At a tank size of 4 Mliters, the intake pipe diameter drops from 1100mm to 1000mm. This drop is the cause for the local minimum in cost seen in Figure 5-11. The biggest factor preventing thermal energy storage from benefitting a Montego Bay SWAC system is the average load. The annual average cooling load in Montego Bay is 62% of the peak load. That leaves 38% of the peak load for the TES tank. The consequence is that TES can only reduce the seawater flow rate by 38%. Most thermal energy storage systems are installed when the annual average load is less than 50% of the peak load.

5.2. PUERTO PLATA

5.2.1. Electrical Cost

A sensitivity study of electrical rate reveals how changes in the cost of electricity impact the relative economics of SWAC and conventional cooling. The economic module of the SWAC model was exercised for a variety of electrical rates centered about the current cost of \$0.32/kW-hr. Figure 5-8 shows the results of the sensitivity study.





Figure 5-8: Comparison of the Effect of Electrical Rate on SWAC and Conventional AC in Puerto Plata

The levelized cost of conventional air conditioning is much more sensitive to electrical rate than is SWAC, as seen by the steeper slope on the red area than the blue area in Figure 5-8. This is due to the fact that the majority of the cost of SWAC is in capital – only a small portion of the lifecycle cost is due to the electrical cost to operate the pumps. In contrast, the majority of the lifecycle cost of conventional air conditioning goes to electricity to operate the chillers. The above relationships mean that SWAC is favored when electrical rates are high, and conventional cooling is favored when electrical rates are low. The cost of electricity in Puerto Plata is high enough the levelized cost of SWAC does not exceed that of conventional cooling within the bounds of the sensitivity study.

Table 5-8 shows the detailed economic output of the sensitivity study.



Table 5-8: Cost Output of Puerto Plata Electrical Rate Sensitivity Study

CostSummary																					
System Specifications																					
Parameter: Electrical Rate (\$/kWh)	0.22	0.23	0.24	0.25	0.26	0.27	0.28	0.29	0.30	0.31	0.32	0.33	0.34	0.35	0.36	0.37	0.38	0.39	0.40	0.41	0.42
Peak AC Load (Tons)	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835
Average AC Load (Tons)	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438
Cost of Electricity (\$/kW-h)	0.22	0.23	0.24	0.25	0.26	0.27	0.28	0.29	0.30	0.31	0.32	0.33	0.34	0.35	0.36	0.37	0.38	0.39	0.40	0.41	0.42
Levelized Cost (\$/ton/year)																					
SWAC Capital Cost	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626	1,626
SWAC Operating Cost	605	620	634	648	662	676	691	705	719	733	748	762	776	790	804	819	833	847	861	876	890
SWAC Periodic Costs	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61
SWAC Total	2,292	2,307	2,321	2,335	2,349	2,364	2,378	2,392	2,406	2,420	2,435	2,449	2,463	2,477	2,492	2,506	2,520	2,534	2,548	2,563	2,577
Conventional AC	3,361	3,494	3,627	3,760	3,893	4,026	4,159	4,292	4,425	4,558	4,691	4,824	4,957	5,091	5,224	5,357	5,490	5,623	5,756	5,889	6,022
Capital Costs																					
Total SWAC Capital Cost	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430	68,430
Diperating Cost																					
Electricity	1.280	1.338	1.396	1.454	1.513	1.571	1.629	1.687	1.745	1.804	1.862	1.920	1.978	2.036	2.094	2,153	2.211	2.269	2,327	2,385	2,443
Maintenance	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Personnel	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65
Subtotal	1,347	1,405	1,463	1,521	1,579	1,638	1,696	1,754	1,812	1,870	1,929	1,987	2,045	2,103	2,161	2,219	2,278	2,336	2,394	2,452	2,510
Total Operating Cost	2.476	2,534	2,593	2.651	2,709	2.767	2.825	2.883	2,942	3.000	3.058	3.116	3,174	3.232	3.291	3.349	3.407	3.465	3.523	3.582	3.640
					,	, .	1	,	,	-)	-)	- / -	- /	- / -	- / -	- /	- / -	.,	- /	- /	
Conventional Air Conditioning																					
Total Comu AC Conital Costa	10.765	10 765	10 765	10.765	10 765	10 765	10 765	10 765	10 765	10 765	10 765	10 765	10.765	10 765	10.765	10 765	10.765	10 765	10.765	10 765	10.765
Annual Conventional AC Costs	10,703	10,703	10,703	10,705	10,703	10,765	10,765	10,703	10,703	10,765	10,703	10,703	10,705	10,703	10,703	10,765	10,765	10,765	10,765	10,765	10,705
Electricity	11,974	12,518	13,062	13,606	14,151	14,695	15,239	15,784	16,328	16,872	17,416	17,961	18,505	19,049	19,593	20,138	20,682	21,226	21,770	22,315	22,859
Water/Sewage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Personnel	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284	284
Maintenance Contract	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103	103
Administration and Overhead	12 702	34	12 701	34	14 970	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34
Total Conv. AC Operating Costs	12,/02	13,247	13,/91	14,335	14,879	15,424	15,908	10,512	17,056	17,001	18,145	10,009	19,233	19,//8	20,322	20,800	21,410	21,955	42,499	23,043	43,387

US.

50



Cooling capital cost is unaffected by electrical rate, and that the SWAC operating cost rises more slowly than the conventional cooling operating cost. The maximum electrical rate considered (\$0.42/kW-hr) represents a 91% increase in electrical cost over the minimum rate (\$0.22/kW-hr). SWAC operating costs rise 47% over this range, while conventional cooling costs rise 86%. The magnitude of the difference is significant, with SWAC operating costs rising by \$1.2 million while conventional cooling cost rises by \$10.9 million. The simple payback period for SWAC varies from 6.7 years at the minimum electrical rate to 3.4 years at the maximum rate.

5.2.2. Cooling Load

SWAC system economics are sensitive to total system size. Larger SWAC systems are typically more economically viable than smaller SWAC systems. The fact that the cooling loads in Puerto Plata are all estimates, and the fact that the cooling equipment in use is unknown for all potential customers, means that there is a large uncertainty in the actual cooling load available for connection to SWAC. To determine how the impact of the uncertainty on the SWAC viability, a sensitivity study on load factor was carried out. The extent of the distribution system is constant for each system size, but the diameter of distribution and offshore pipes used is varied as the chilled water flow rate varies. The onshore pipe diameters are not optimized for each load factor, so the levelized cost at a load factor of 1.0 is slightly higher than that shown in Table 3-7.

Figure 5-9 shows the impact of load factor on SWAC levelized cost.



Figure 5-9: Comparison of the Effect of Load Factor on SWAC and Conventional AC in Puerto Plata

A SWAC system in Puerto Plata is slightly more sensitive to load reduction than load increase. This is visible in that the slope of the blue area in Figure 5-9 is generally steeper on the left side of the plot than the right. The unevenness in slope is due to the fact that the offshore pipe costs change in discrete increments (pipe

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



diameters). SWAC is cost competitive with conventional cooling over the entire range of the sensitivity study, which indicates that uncertainty in total cooling load does not pose a large risk to SWAC system economic viability. Table 5-9 shows the detailed cost output from the sensitivity study.

0.50	0.60	0.70	0.80	0.90	1.00	1.10	1.20	1.30	1.40	1.50
3,418	4,101	4,785	5,468	6,152	6,835	7,519	8,202	8,886	9,569	10,253
2,219	2,663	3,107	3,550	3,994	4,438	4,882	5,325	5,769	6,213	6,657
0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32
2,298	2,117	1,918	1,943	1,790	1,666	1,607	1,519	1,480	1,422	1,360
1,009	924	858	788	788	733	738	730	700	706	704
94	83	76	69	65	61	58	56	54	52	51
3,400	3,124	2,851	2,800	2,643	2,461	2,403	2,304	2,235	2,180	2,114
4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691
24 948	28.070	28 166	34 572	34 581	34 725	36 279	36 494	38 157	38 405	38 563
24,740	20,070	20,100	54,572	54,501	54,725	50,277	50,777	50,157	50,405	50,505
8,054	8,614	9,781	10,582	11,748	12,306	13,738	14,964	15,755	16,974	18,242
11,673	12,965	14,739	16,235	17,470	19,071	20,327	21,191	23,000	24,330	24,953
19 260	53 470	56 510	65 420	67 820	70 120	74 410	76 710	Q1 010	03 000	95 950
40,000	33,470	30,310	03,420	07,020	70,130	/4,410	/0,/10	01,010	03,000	03,030
1,152	1,309	1,453	1,527	1,806	1,864	2,141	2,364	2,464	2,745	2,983
90	95	99	104	109	114	119	124	129	133	138
			-			-				
2,063	2,267	2,456	2,580	2,901	3,000	3,320	3,582	3,725	4,044	4,319
5,383	6,459	7,536	8,612	9,689	10,765	11,842	12,918	13,995	15,071	16,148
9,072	10,887	12,701	14,516	16,330	18,145	19,959	21,774	23,588	25,403	27,217
	0.50 3,418 2,219 0.32 2,298 1,009 94 3,400 4,691 24,948 8,054 11,673 48,360 1,152 90 2,063 5,383 9,072	0.50 0.60 3,418 4,101 2,219 2,663 0.32 0.32 2,298 2,117 1,009 924 94 83 3,400 3,124 4,691 4,691 24,948 28,070 8,054 8,614 11,673 12,965 48,360 53,470 11,152 1,309 90 95 2,063 2,267 10,53 6,459 9,072 10,887	No.50 0.60 0.70 3,418 4,101 4,785 2,219 2,663 3,107 0.32 0.32 0.32 2,298 2,117 1,918 1,009 924 858 94 83 76 3,400 3,124 2,851 4,691 4,691 4,691 4,691 4,691 4,691 24,948 28,070 28,166 8,054 8,614 9,781 11,673 12,965 14,739 48,360 53,470 56,510 11,152 1,309 1,453 90 9,5 9,99 2,063 2,267 2,456 10,87 1,98 7,536 9,072 10,887 12,701	No.50 0.60 0.70 0.80 3,418 4,101 4,785 5,468 2,219 2,663 3,107 3,550 0.32 0.32 0.32 0.32 2,298 2,117 1,918 1,943 1,009 924 858 788 94 83 76 69 3,400 3,124 2,851 2,800 4,691 4,691 4,691 4,691 4,691 4,691 4,691 4,691 24,948 28,070 28,166 34,572 8,054 8,614 9,781 10,582 11,673 12,965 14,739 16,235 48,360 53,470 56,510 65,420 11,152 1,309 1,453 1,527 90 95 99 104 2,063 2,267 2,456 2,580 5,383 6,459 7,536 8,612 9,072 10,887	0.50 0.60 0.70 0.80 0.90 3,418 4,101 4,785 5,468 6,152 2,219 2,663 3,107 3,550 3,994 0.32 0.32 0.32 0.32 0.32 2,298 2,117 1,918 1,943 1,790 1,009 924 858 788 788 94 83 76 69 65 3,400 3,124 2,851 2,800 2,643 4,691 4,691 4,691 4,691 4,691 24,948 28,070 28,166 34,572 34,581 8,054 8,614 9,781 10,582 11,748 11,673 12,965 14,739 16,235 17,470 48,360 53,470 56,510 65,420 67,820 11,152 1,309 1,453 1,527 1,806 90 95 99 104 109 2,063 2,267	0.50 0.60 0.70 0.80 0.90 1.00 $3,418$ $4,101$ $4,785$ $5,468$ $6,152$ $6,835$ $2,219$ $2,663$ $3,107$ $3,550$ $3,994$ $4,438$ 0.32 0.32 0.32 0.32 0.32 0.32 $2,298$ $2,117$ $1,918$ $1,943$ $1,790$ $1,666$ $1,009$ 924 858 788 788 733 94 83 76 69 65 611 $3,400$ $3,124$ $2,851$ $2,800$ $2,643$ $2,461$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $24,948$ $28,070$ $28,166$ $34,572$ $34,581$ $34,725$ $8,054$ $8,614$ $9,781$ $10,582$ $11,748$ $12,306$ $11,673$ $12,965$ $14,739$ $16,235$ $17,470$ $19,071$ $48,360$ $53,470$ $56,510$ $65,420$ $67,820$ $70,130$ $1,152$ $1,309$ $1,453$ $1,527$ $1,806$ $1,864$ 90 95 99 104 109 114 $2,063$ $2,267$ $2,456$ $2,580$ $2,901$ $3,000$ $5,383$ $6,459$ $7,536$ $8,612$ $9,689$ $10,765$ $9,9072$ $10,887$ $12,701$ $14,516$ <t< td=""><td>0.50$0.60$$0.70$$0.80$$0.90$$1.00$$1.10$$3,418$$4,101$$4,785$$5,468$$6,152$$6,835$$7,519$$2,219$$2,663$$3,107$$3,550$$3,994$$4,438$$4,882$$0.32$$0.32$$0.32$$0.32$$0.32$$0.32$$0.32$$0.32$$2,298$$2,117$$1,918$$1,943$$1,790$$1,666$$1,607$$1,009$$924$$858$$788$$788$$733$$738$$94$$83$$76$$69$$65$$61$$58$$3,400$$3,124$$2,851$$2,800$$2,643$$2,461$$2,403$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$4,691$$24,948$$28,070$$28,166$$34,572$$34,581$$34,725$$36,279$$8,054$$8,614$$9,781$$10,582$$11,748$$12,306$$13,738$$11,673$$12,965$$14,739$$16,235$$17,470$$19,071$$20,327$$48,360$$53,470$$56,510$$65,420$$67,820$$70,130$$74,410$$9$$9$$9$$104$$109$$114$$119$$1,152$$1,309$$1,453$$1,527$$1,806$$1,864$$2,141$$9$$9,5$$9,99$$104$$109$$114$$119$$9,072$<t< td=""><td>No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 3,418 4,101 4,785 5,468 6,152 6,835 7,519 8,202 2,219 2,663 3,107 3,550 3,994 4,438 4,882 5,325 0.32 3.400 3.403 2.4643 2.464 2.4643</td><td>No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 1.30 3.418 4,101 4,785 5.468 6.152 6.835 7.519 8.202 8.886 2.219 2.663 3,107 3.550 3.994 4.438 4.882 5.325 5.769 0.32 3.30 700 7</td><td>Image: big big big big big big big big big big</td></t<></td></t<>	0.50 0.60 0.70 0.80 0.90 1.00 1.10 $3,418$ $4,101$ $4,785$ $5,468$ $6,152$ $6,835$ $7,519$ $2,219$ $2,663$ $3,107$ $3,550$ $3,994$ $4,438$ $4,882$ 0.32 0.32 0.32 0.32 0.32 0.32 0.32 0.32 $2,298$ $2,117$ $1,918$ $1,943$ $1,790$ $1,666$ $1,607$ $1,009$ 924 858 788 788 733 738 94 83 76 69 65 61 58 $3,400$ $3,124$ $2,851$ $2,800$ $2,643$ $2,461$ $2,403$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $4,691$ $24,948$ $28,070$ $28,166$ $34,572$ $34,581$ $34,725$ $36,279$ $8,054$ $8,614$ $9,781$ $10,582$ $11,748$ $12,306$ $13,738$ $11,673$ $12,965$ $14,739$ $16,235$ $17,470$ $19,071$ $20,327$ $48,360$ $53,470$ $56,510$ $65,420$ $67,820$ $70,130$ $74,410$ 9 9 9 104 109 114 119 $1,152$ $1,309$ $1,453$ $1,527$ $1,806$ $1,864$ $2,141$ 9 $9,5$ $9,99$ 104 109 114 119 $9,072$ <t< td=""><td>No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 3,418 4,101 4,785 5,468 6,152 6,835 7,519 8,202 2,219 2,663 3,107 3,550 3,994 4,438 4,882 5,325 0.32 3.400 3.403 2.4643 2.464 2.4643</td><td>No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 1.30 3.418 4,101 4,785 5.468 6.152 6.835 7.519 8.202 8.886 2.219 2.663 3,107 3.550 3.994 4.438 4.882 5.325 5.769 0.32 3.30 700 7</td><td>Image: big big big big big big big big big big</td></t<>	No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 3,418 4,101 4,785 5,468 6,152 6,835 7,519 8,202 2,219 2,663 3,107 3,550 3,994 4,438 4,882 5,325 0.32 3.400 3.403 2.4643 2.464 2.4643	No. No. No. No. No. No. No. 0.50 0.60 0.70 0.80 0.90 1.00 1.10 1.20 1.30 3.418 4,101 4,785 5.468 6.152 6.835 7.519 8.202 8.886 2.219 2.663 3,107 3.550 3.994 4.438 4.882 5.325 5.769 0.32 3.30 700 7	Image: big

Table 5-9: Cost Output of Puerto Plata Load Factor Sensitivity Study

The levelized cost of conventional cooling is unaffected by changes in load factor. This is because both the capital and operating costs of conventional cooling scale linearly with cooling load. SWAC, however, exhibits an economy of scale; both capital and operating costs rise more slowly with increasing load. The maximum cooling load (150% of the expected load) represents a 300% increase over the minimum cooling load (50% of the expected load). Over this range, SWAC capital costs increase by 178%, and SWAC operating costs increase by 209%. Conventional cooling capital cost and operating cost increases by 300%. The simple payback period varies from 6.9 years at the minimum load to 3.7 years at the maximum load.

Table 5-10 shows the technical differences in SWAC system design for the different load factors.



Technical Summary											
Parameter: Load Factor	0.5	0.6	0.7	0.8	0.9	1	1.1	1.2	1.3	1.4	1.5
Peak AC Load (Tons)	3417.5	4101	4784.5	5468	6151.5	6835	7518.5	8202	8885.5	9569	10252.5
Average AC Load (Tons)	2219	2663	3107	3550	3994	4438	4882	5325	5769	6213	6657
Intake Pipe											
Depth of Intake (m)	-1223	-1189	-1137	-1129	-1098	-1082	-1081	-1069	-1070	-1061	-1053
Length of Intake Pipe (m)	8711	8536	8270	8230	8073	7992	7986	7926	7931	7883	7845
Outside Diameter of Intake Pipe (m)	0.90	1.00	1.00	1.10	1.10	1.10	1.20	1.20	1.30	1.30	1.30
Deep Water Temperature (°C)	5.11	5.25	5.51	5.55	5.71	5.81	5.82	5.90	5.90	5.96	6.01
Return Pipe											
Outside Diameter of Return Pipe (m)	0.56	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80
Max Temperature of Returned Water (°C)	12.80	12.70	12.63	12.57	12.53	12.49	12.47	12.44	12.42	12.41	12.39
Seawater Pump Station											
Mass Flow (kg/s)	380	456	532	609	685	761	837	913	989	1065	1141
Seawater pumping power (kW)	115	100	121	146	171	200	231	266	302	344	390
Chilled Water Pump Station											
Total Flow (kg/s)	362	434	507	579	651	724	796	869	941	1013	1086
Freshwater pumping power (kW)	203	255	278	282	337	333	383	417	419	461	491
Heat Exchangers											
SW dT Across Heat Exchanger (°C)	5.82	5.81	5.81	5.80	5.80	5.80	5.79	5.79	5.79	5.79	5.79
SW Flow (kg/s)	380	456	532	609	685	761	837	913	989	1065	1141
FW Flow (kg/s)	362	434	507	579	651	724	796	869	941	1013	1086
TEC Toples											
TES Peak Elow (kg/s)	1/0//0	170 20	200.20	230.19	260 00	208 00	378 00	358 70	300 20	118 57	118 17
TES Topk Consoity (MI)	149.49	6 40	209.29	237.18	209.08	290.98	320.88 11.74	12 90	200.00	410.37	16.00
TES Tank Capacity (MI)	3.33	0.40	1.47	0.33	9.60	10.07	11./4	12.80	13.87	14.94	10.00

Table 5-10: Technical Output of Puerto Plata Load Factor Sensitivity Study

The offshore pipe diameters change 0.4m diameter over the range of cooling loads; the intake pipe varies from 900 mm diameter to 1300 mm diameter, while the return pipe varies between 560 mm and 800 mm. The intake pipe must also go deeper at reduced load. This is to account for the fact that pipes with lower flow rates are more subject to warming than pipes with higher flow rates. The seawater pump energy, chilled water pump energy, and heat exchanger area also scale with the cooling load. Low load factors require less water flow and less heat transfer area than high load factors.

5.2.3. Hybrid SWAC

Hybrid SWAC is an alternative SWAC design concept that uses chillers to supplement seawater cooling. See section 5.1.2 for a description of how hybrid SWAC works.

Makai investigated the benefit of hybrid SWAC by performing a sensitivity study on auxiliary chiller temperature drop. The sensitivity study can determine whether hybrid SWAC is cost effective, as well as the temperature drop at which a cost effective system should operate. Figure 5-10 shows the impact of hybrid SWAC on the Puerto Plata system.





Figure 5-10: The Effect of Hybrid SWAC on Levelized Cost in Puerto Plata

Hybrid SWAC is not cost effective in Puerto Plata – the minimum levelized cost on the curve is where the temperature drop is zero (pure SWAC). This conclusion is extremely sensitive to the assumed bathymetric profile. Hybrid SWAC is typically cost effective when there is a long flat section of seabed just inshore of the depth at which a pure SWAC intake would be placed. Since no detailed bathymetry offshore of Puerto Plata is available, it is unknown whether such a plateau exists. The assumed bathymetric profile assumes a steady increase in depth, so it is unsurprising that hybrid SWAC is not cost effective. Figure 5-11 shows the detailed cost output of the hybrid SWAC sensitivity study.

0.40									
Cost Summary									
System Specifications			1 50		4.00				
Parameter: Chiller Delta T (°C)	-2.00	-1.75	-1.50	-1.25	-1.00	-0.75	-0.50	-0.25	0.00
Peak AC Load (Tons)	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835
Average AC Load (Tons)	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438
Cost of Electricity (\$/kW-h)	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32
Levelized Cost									
SWAC Capital Cost	1,731	1,724	1,717	1,712	1,706	1,699	1,697	1,696	1,673
SWAC Operating Cost	2,034	1,885	1,735	1,586	1,436	1,287	1,137	987	730
SWAC Periodic Costs	63	63	63	63	63	63	63	63	61
SWAC Total	3,828	3,672	3,515	3,360	3,205	3,049	2,896	2,746	2,465
Conventional AC	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691
Capital Costs (k\$)									
Offshore Seawater Pipes Total	33,164	33,272	33,380	33,597	33,778	33,902	34,203	34,563	34,725
Pump Station Total	16,256	15,850	15,426	15,014	14,594	14,174	13,756	13,364	12,287
Distribution Network Total	19,436	19,436	19,436	19,436	19,436	19,436	19,436	19,436	19,391
Total SWAC Capital Cost	72,870	72,570	72,250	72,060	71,820	71,530	71,420	71,390	70,430
Operating Cost (k\$/year)									
Pumps Subtotal Chillers	2,287	2,287	2,288	2,288	2,288	2,288	2,288	2,288	1,850
Subtotal TES Tanks	4,893	4,282	3,671	3,059	2,448	1,836	1,224	612	0
Subtotal	462	462	462	462	462	462	462	462	462
Total Operating Cost	8,323	7,711	7,099	6,487	5,876	5,263	4,651	4,039	2,988
Conventional Air Conditioning									
Total Conv. AC Capital Costs Total Conv. AC Operating Costs	10,765 18,145								

Table 5-11: Cost Output of Pu	erto Plata Hybrid SWAC	Sensitivity Study
--------------------------------------	------------------------	-------------------

As auxiliary chiller temperature change becomes more negative (increased chiller temperature drop), the cost of the offshore pipes decreases, and the cost of the pump station increases. The decrease in offshore pipe cost is due to decreasing intake depth, while the increase in pump station cost is due to an increase in the cost to purchase auxiliary chillers. The decrease in pipe cost is smaller than the increase in chiller cost; it is more expensive to purchase chillers than it is to purchase a longer intake pipe. The incremental cost of intake pipe is the factor that is sensitive to seabed slope. The steady slope in the assumed bathymetric profile is the root cause of the small changes in offshore pipe cost. The SWAC operating cost rises dramatically as chiller temperature change becomes more negative. This represents the increasing amount of electricity consumed by the chiller.

Table 5-12 shows the technical differences in SWAC system design due at the various chiller temperature drops considered.



Technical Summary									
Parameter: Chiller DeltaT (°C)	-2	-1.75	-1.5	-1.25	-1	-0.75	-0.5	-0.25	0
Peak AC Load (Tons)	6835	6835	6835	6835	6835	6835	6835	6835	6835
Average AC Load (Tons)	4438	4438	4438	4438	4438	4438	4438	4438	4438
Intake Pipe									
Depth of Intake (m)	-851	-875	-899	-926	-952	-979	-1008	-1045	-1082
Length of Intake Pipe (m)	6939	7042	7144	7257	7370	7483	7612	7801	7992
Outside Diameter of Intake Pipe (m)	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10
Deep Water Temperature (°C)	7.86	7.60	7.34	7.09	6.83	6.58	6.32	6.07	5.81
Return Pipe									
Outside Diameter of Return Pipe (m)	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80
Max Temperature of Returned Water (°C)	15.02	14.70	14.39	14.07	13.76	13.44	13.12	12.81	12.49
Seawater Pump Station									
Mass Flow (kg/s)	760	760	760	760	760	760	760	761	761
Seawater pumping power (kW)	197	197	197	198	198	198	198	198	198
Chilled Water Pump Station									
Total Flow (kg/s)	724	724	724	724	724	724	724	724	724
Freshwater pumping power (kW)	487	487	487	486	486	486	486	486	330
Heat Exchangers									
SW dT Across Heat Exchanger (°C)	6.37	6.30	6.23	6.16	6.09	6.01	5.94	5.87	5.80
SW Flow (kg/s)	760	760	760	760	760	760	760	761	761
FW Flow (kg/s)	724	724	724	724	724	724	724	724	724
TES Tanks									
TES Peak Flow (kg/s)	298.98	298.98	298.98	298.98	298.98	298.98	298.98	298.98	298.98
TES Tank Capacity (Ml)	10.67	10.67	10.67	10.67	10.67	10.67	10.67	10.67	10.67

Table 5-12: Technical Output of Puerto Plata Hybrid SWAC Sensitivity Study

The cold water intake depth decreases as chiller temperature change becomes more negative (larger temperature drop). However, the change in length is not enough to allow a reduction in intake pipe diameter. This is another factor that minimizes the savings from hybrid SWAC at Puerto Plata.

5.2.4. Thermal Energy Storage

Thermal energy storage (TES) is a method of evening out daily variations in cooling load. The style of thermal energy storage used in the SWAC model is chilled water storage. See section 5.1.3 for a description of thermal energy storage operation. A sensitivity study to analyze TES was used in order to determine both its overall economic viability and the optimum TES tank size. Figure 5-11 shows the results of the Montego Bay TES system sensitivity study.





Figure 5-11: The Effect of TES Tank Capacity on SWAC Levelized Cost in Puerto Plata

Thermal energy storage is a benefit to the Puerto Plata SWAC system. Although TES tanks sized to handle only part of the peak load result in increased levelized cost, a full-sized tank that minimizes the size of the seawater system results in a decrease in levelized cost. The conclusion that thermal energy storage benefits the Puerto Plata system was taken into account when doing the final modeling. The results presented in section 3.2 include a full-size thermal energy storage system.

0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00
6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835	6,835
4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438	4,438
0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32
1,720	1,738	1,735	1,705	1,707	1,706	1,708	1,708	1,709	1,710	1,712	1,676
716	765	755	749	744	740	738	735	734	732	731	733
69	69	68	67	66	65	64	64	63	62	62	61
2,506	2,572	2,558	2,521	2,517	2,512	2,510	2,507	2,506	2,504	2,505	2,470
4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691	4,691
28 777	38 146	38 044	26 281	36 400	26 228	36 336	36 273	36 206	26 120	36 128	34 725
36,777	36,140	36,044	50,561	30,400	50,556	30,330	30,273	30,200	50,159	30,128	34,723
10,154	11,536	11,502	11,944	11,987	12,030	12,103	12,183	12,276	12,361	12,478	12,395
19,359	19,399	19,398	19,397	19,396	19,395	19,395	19,394	19,393	19,392	19,392	19,391
72 400	72 100	72.040	71 700	71 050	71.020	71.000	71.010	71.040	71.070	72.000	70 5 10
72,400	/3,180	/3,040	/1,/80	/1,850	/1,830	/1,900	/1,910	/1,940	/1,960	72,060	70,540
2,198	2,272	2,203	2,145	2,095	2,051	2,009	1,971	1,935	1,901	1,870	1,850
132	129	127	125	124	122	120	119	118	116	115	114
102		127	120	12.	122	120	,	110	110	110	
2,931	3,128	3,090	3,062	3,043	3,029	3,017	3,008	3,001	2,995	2,992	2,997
10.765	10.765	10.765	10.765	10.765	10.765	10.765	10.765	10.765	10.765	10.765	10.765
18.145	18.145	18.145	18.145	18.145	18,145	18.145	18.145	18.145	18,145	18.145	18.145
	0.00 6,835 4,438 0.32 1,720 716 69 2,506 4,691 38,777 10,154 19,359 72,400 2,198 132 2,931 10,765 18,145	0.00 1.00 6,835 6,835 4,438 4,438 0.32 0.32 1,720 1,738 716 765 69 69 2,506 2,572 4,691 4,691 38,777 38,146 10,154 11,536 19,359 19,399 72,400 73,180 2,198 2,272 132 129 2,193 3,128 10,765 10,765 10,755 10,765	Image Image 0.00 1.00 2.00 6.835 6.835 6.835 4.438 4.438 4.438 0.32 0.32 0.32 1,720 1,738 1,735 716 765 755 69 69 68 2,506 2,572 2,558 4,691 4,691 4,691 38,777 38,146 38,044 10,154 11,536 11,502 19,359 19,399 19,398 72,400 73,180 73,040 2,198 2,272 2,203 132 129 127 2,193 3,128 3,090 10,765 10,765 10,765 10,765 10,765 10,765	Image Image Image 0.00 1.00 2.00 3.00 6.835 6.835 6.835 6.835 4.438 4.438 4.438 4.438 0.32 0.32 0.32 0.32 1.720 1.738 1.735 1.705 716 765 755 749 69 69 68 67 2.506 2.572 2.558 2.521 4.691 4.691 4.691 4.691 4.691 4.691 4.691 4.691 38,777 38,146 38,044 36,381 10,154 11,536 11,502 11,944 19,359 19,399 19,398 19,397 72,400 73,180 73,040 71,780 72,400 73,180 73,040 71,780 10,755 12,293 2,115 12,55 2,198 2,272 2,203 2,145 132 129 127	0.00 1.00 2.00 3.00 4.00 0.00 1.00 2.00 3.00 4.00 6.835 6.835 6.835 6.835 6.835 4.438 4.438 4.438 4.438 4.438 0.32 0.32 0.32 0.32 0.32 1.720 1.738 1.735 1.705 1.707 716 765 755 749 744 69 68 67 66 2.506 2.572 2.558 2.521 2.517 4.691 4.691 4.691 4.691 4.691 4.691 4.691 4.691 4.691 4.691 $38,777$ $38,146$ $38,044$ $36,381$ $36,400$ $10,154$ $11,536$ $11,502$ $11,944$ $11,987$ $19,359$ $19,399$ $19,398$ $19,397$ $19,396$ $72,400$ $73,180$ $73,040$ $71,780$ $71,850$ $10,755$ 122 2.203 2.145 2.095 132 129 127 125 124 $2,931$ $3,128$ $3,090$ $3,062$ $3,043$ $10,765$ $10,765$ $10,765$ $10,765$ $10,765$	Nome Nome Nome Nome Nome 0.00 1.00 2.00 3.00 4.00 5.00 6.835 6.835 6.835 6.835 6.835 6.835 4.438 4.438 4.438 4.438 4.438 0.32 0.32 0.32 0.32 0.32 1,720 1,738 1,735 1,705 1,707 1,706 716 765 755 749 744 740 69 69 68 67 66 65 2,506 2,572 2,558 2,521 2,517 2,512 4,691 4,691 4,691 4,691 4,691 4,691 4,691 4,691 4,691 4,691 38,777 38,146 38,044 36,381 36,400 36,338 10,154 11,536 11,502 11,944 11,987 12,030 19,359 19,399 19,398 19,397 19,396 19,395	0.00 1.00 2.00 3.00 4.00 5.00 6.00 6.835 6.835 6.835 6.835 6.835 6.835 6.835 6.835 4.438 4.438 4.438 4.438 4.438 4.438 4.438 0.32 0.32 0.32 0.32 0.32 0.32 0.32 1.720 1.738 1.735 1.705 1.707 1.706 1.708 716 765 755 749 744 740 738 69 68 67 66 65 64 2.506 2.572 2.558 2.521 2.517 2.512 2.510 4.691 $3.8,777$ $38,146$ $38,044$ $36,381$ $36,400$ $36,338$ $36,336$ $10,154$ $11,536$ $11,502$ $11,944$ $11,987$ $12,030$ $12,103$ $19,395$ $19,399$ $19,398$ $19,397$ $19,396$ $19,395$ $19,395$ $72,400$ $73,180$ $73,040$ $71,780$ $71,850$ $71,850$ $71,850$ $71,850$ $10,755$ $12,292$ $2,203$ $2,1152$ $12,212$ 1202 1202 $2,198$ $2,272$ $2,203$ $2,145$ $2,095$ $2,051$ <td>0.00$1.00$$2.00$$3.00$$4.00$$5.00$$6.00$$7.00$$6.835$$7.02$$0.32$<t< td=""><td>Image: big big big big big big big big big big</td><td>Image Image <th< td=""><td>Image Image <th< td=""></th<></td></th<></td></t<></td>	0.00 1.00 2.00 3.00 4.00 5.00 6.00 7.00 6.835 7.02 0.32 <t< td=""><td>Image: big big big big big big big big big big</td><td>Image Image <th< td=""><td>Image Image <th< td=""></th<></td></th<></td></t<>	Image: big	Image Image <th< td=""><td>Image Image <th< td=""></th<></td></th<>	Image Image <th< td=""></th<>

Table 5-13: Technical Output of Puerto Plata TES Tank Sensitivity Study

The cost of the offshore pipe decreases as tank capacity increases. This is driven by the reduction in required seawater flow rate. Reduced flow rate allows use of thinner pipe wall and/or reduced pipe diameter, both of which reduce cost. The total capital cost of the SWAC system increases for small tanks, but decreases for larger tanks. Any TES tank larger than 3 Mliters will reduce the total capital cost of the SWAC system. The operating cost for midsize tanks is larger than savings from reduced seawater pumping. This increased operating cost means that a TES tank must be at least 9 Mliters before it can compete with the non-TES SWAC system on a levelized cost basis. There is a decrease in both capital cost and levelized cost at the full-size 11 Mliter tank.

Table 5-7 shows the technical SWAC design differences at the different tank sizes considered.



Technical Summary												
Parameter: TES Tank Capacity (Ml)	0	1	2	3	4	5	6	7	8	9	10	11
Peak AC Load (Tons)	6835	6835	6835	6835	6835	6835	6835	6835	6835	6835	6835	6835
Average AC Load (Tons)	4438	4438	4438	4438	4438	4438	4438	4438	4438	4438	4438	4438
Intake Pipe												
Depth of Intake (m)	-1041	-1050	-1057	-1053	-1058	-1064	-1069	-1075	-1081	-1087	-1092	-1082
Length of Intake Pipe (m)	7779	7826	7863	7842	7870	7899	7927	7956	7985	8015	8044	7992
Outside Diameter of Intake Pipe (m)	1.30	1.30	1.30	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.10
Deep Water Temperature (°C)	6.10	6.03	5.99	6.01	5.98	5.94	5.90	5.86	5.82	5.78	5.75	5.81
Return Pipe												
Outside Diameter of Return Pipe (m)	0.90	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80
Max Temperature of Returned Water (°C)	12.40	12.41	12.42	12.43	12.44	12.44	12.45	12.46	12.47	12.48	12.49	12.49
Seawater Pump Station												
Mass Flow (kg/s)	1075	1022	984	951	922	895	869	844	820	797	775	761
Seawater pumping power (kW)	288	320	300	283	269	256	244	233	222	213	204	198
Chilled Water Pump Station												
Total Flow (kg/s)	1023	973	937	905	878	852	827	803	780	759	738	724
Freshwater pumping power (kW)	472	448	431	416	402	390	378	367	357	346	337	330
Heat Exchangers												
SW dT Across Heat Exchanger (°C)	5.65	5.68	5.69	5.71	5.72	5.74	5.75	5.76	5.77	5.78	5.79	5.80
SW Flow (kg/s)	1075	1022	984	951	922	895	869	844	820	797	775	761
FW Flow (kg/s)	1023	973	937	905	878	852	827	803	780	759	738	724
TES Tanks												
TES Peak Flow (kg/s)	0.00	50.00	86.04	117.43	145.21	171.03	196.03	219.53	242.26	264.21	285.05	298.98
TES Tank Capacity (MI)	0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00

Table 5-14: Technical Output of Puerto Plata TES Tank Sensitivity Study

Seawater flow rate decreases as tank size increases. At a tank size of 3 Mliters, the intake pipe diameter drops from 1300mm to 1200mm. There is another drop down to 1100mm at a tank size of 11 Mliters. These changes in pipe diameter are responsible for the drops in levelized cost seen in Figure 5-11. The reason TES makes economic sense in Puerto Plata is that the cold water intake pipe is extremely long. At 8 km, an intake pipe at Puerto Plata would be the longest intake pipeline installed to date. The length of the pipe magnifies any savings due to reduction in pipe diameter. The fact that a full-size TES tank reduces the pipe diameter from 1300mm to 1100mm saves enough money on the pipe to pay for the tank.



6. **RISK ANALYSIS**

As part of the conceptual design for the Puerto Plata and Montego Bay SWAC systems Makai has used publically available databases to assess the risks due to earthquakes and hurricanes. Earthquakes pose the greatest risk to rigid structures within the pipelines, such tunnel or trench breakouts, stiff mitered joints, or within the pump station. The HDPE pipelines themselves are extremely durable and flexible and failures due to seismic activity are not likely to occur along the flexible portions. Hurricanes can generate large waves which pose considerable risk to pipelines on the seafloor (typical in water depths less than 150m). These risks can be mitigated with proper design and anchoring to the seafloor. Hurricanes would also have the potential generate substantial damage to buildings such as the pump station due to the high winds and coastal flooding.

6.1. HURRICANES

6.1.1. Montego Bay

Historical hurricane information from the National Oceanographic and Atmospheric Association (NOAA) shows that Jamaica has only received a direct hit from one major hurricane since records began. However, multiple category 4 and category 5 hurricanes have passed nearby. Figure 6-1 shows the hurricanes above category 3 (major hurricanes) that have passed Jamaica since 1842.



Figure 6-1: Major Hurricanes near Jamaica Since 1842

Dark purple lines represent category 5 hurricanes, light purple lines represent category 4 hurricanes, and red lines represent category 3 hurricanes. Three storms of particular interest are listed below:

- Hurricane Allen (1980) category 5 hurricane that was downgraded to a category 4 as is passed north of Jamaica.
- Hurricane Ivan (2005) category 4 hurricane that passed south of Jamaica.
- Hurricane Dean (2007) category 5 hurricane that was downgraded to a category 4 as it passed south of Jamaica.



All three of these storms had the potential for a direct hit. Even without direct impact, all three storms caused extensive damage. Makai recommends that a Montego Bay SWAC system be designed to withstand a direct hit from a category 5 hurricane.

6.1.2. Puerto Plata

Historical hurricane data from NOAA shows that the Dominican Republic has been hit by 3 major hurricanes since records began. Another major hurricane passed north of the island. Figure 6-2 shows the major hurricanes that have passed the Dominican Republic since 1842.



Figure 6-2: Major Hurricanes near the Dominican Republic since 1842

Dark purple lines represent category 5 hurricanes, light purple lines represent category 4 hurricanes, and red lines represent category 3 hurricanes. Three storms of particular interest are listed below:

- Okeechobee Hurricane (1928) category 5 hurricane that passed north of the Dominican Republic, near Puerto Plata.
- Dominican Republic Hurricane (1930) category 5 hurricane that hit to the southwest of Santo Domingo.
- Hurricane David (1979) category 5 hurricane that hit to the southwest of Santo Domingo.

The two storms that hit near Santo Domingo caused extensive damage.

6.1.3. Risk Mitigation

Makai recommends that a Puerto Plata SWAC system be designed to withstand a direct hit from a category 5 hurricane.

6.2. <u>EARTHQUAKES</u>

6.2.1. Montego Bay

Jamaica sits in a seismically active area. Dr. Ducan Agnew of the Scripps Institute of Oceanography has compiled a Google Earth KMZ file showing earthquakes with a magnitude greater than 6.5 (on the Richter scale) since 1990. An excerpt from the file is shown in

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



Figure 6-3.



Figure 6-3: Earthquakes near Jamaica since 1900

Five earthquakes have been recorded near Jamaica, including two with a magnitude over 7.0.

The Global Seismic Hazard Assessment Program (GSHAP) works with multiple national geological research organizations to create estimates of seismic risks around the world. The seismic hazard is rated by the expected peak ground acceleration. A ground acceleration of 2 m/s² is associated with a strong earthquake capable of moderate structure damage. As a point of reference, the 2010 earthquake in Haiti had a peak ground acceleration of 4.9 m/s². Figure 6-4 is a map shaded to show the estimated seismic hazard around Jamaica.





Figure 6-4: GSHAP Seismic Hazard Map of Jamaica

The greatest risk is on the south side of the island, away from Montego Bay.

Table 6-1 shows the specific ground acceleration estimates near Montego Bay.

Latitude	Longitude	Acceleration
[deg]	[deg]	[m/s^2]
18.4	-78.0	2.2
18.4	-77.9	2.3
18.4	-77.8	2.3
18.5	-78.0	2.2
18.5	-77.9	2.3
18.5	-77.8	2.4
18.6	-78.0	2.3
18.6	-77.9	2.3
18.6	-77.8	2.4

Table 6-1: GSHAP Peak Ground Acceleration Estimates near Montego Bay

The GSHAP rates Montego Bay at the upper end of the "Moderate Hazard" category.

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN

63



6.2.2. Puerto Plata

The Dominican Republic sits in a seismically active area. Dr. Ducan Agnew of the Scripps Institute of Oceanography has compiled a Google Earth KMZ file showing earthquakes with a magnitude greater than 6.5 (on the Richter scale) since 1990. An excerpt from the file is shown in Figure 6-5.



Figure 6-5: Earthquakes near the Dominican Republic since 1900

Seventeen earthquakes have been recorded near the Dominican Republic, including seven with a magnitude over 7.0.

The Global Seismic Hazard Assessment Program (GSHAP) works with multiple national geological research organizations to create estimates of seismic risks around the world. The seismic hazard is rated by the expected peak ground acceleration. A ground acceleration of 2 m/s^2 is associated with a strong earthquake capable of moderate structure damage. As a point of reference, the 2010 earthquake in Haiti had a peak ground acceleration of 4.9 m/s^2 . Figure 6-6 is a map shaded to show the estimated seismic hazard around the Dominican Republic.





Figure 6-6: GSHAP Seismic Hazard Map of the Dominican Republic

The greatest risk is on the south side of the island, away from Puerto Plata.

Table 6-2 shows the specific ground acceleration estimates near Montego Bay.

Latitude	Longitude	Acceleration
[deg]	[deg]	[m/s^2]
19.7	-70.8	3.1
19.7	-70.7	3.2
19.7	-70.6	3.3
19.8	-70.8	3.1
19.8	-70.7	3.2
19.8	-70.6	3.3
19.9	-70.8	3.1
19.9	-70.7	3.2
19.9	-70.6	3.3

Table 6-2: GSHAP Peak Ground Acceleration Estimates near Puerto Plata

The GSHAP rates Puerto Plata near the middle of the "High Hazard" category. A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



6.2.3. Risk Mitigation

The seismic risk of a SWAC system can be separated into two categories: onshore and offshore. Makai recommends that the design of the onshore components of a SWAC system at both sites be supported by geotechnical and/or structural engineers familiar with seismically robust buildings as well as local building codes. Use of HDPE for the distribution system will increase the resiliency of the system. Though HDPE pipes will not withstand large scale ground movement, they can accommodate significantly more motion than steel pipes.

Evaluation of offshore seismic risk will require a detailed seabed survey. The survey may include highresolution bathymetric data, sub-bottom sonar data, video of the seabed, and seabed samples. An offshore geotechnical engineer will be required to evaluate the seismic risk to the offshore pipes during an earthquake. The primary risk is likely to be collapse of a portion of the seabed. A collapsing seabed will move downhill, and will drag the pipe with it. This situation can put significant tension in the pipe and could cause it to fail. Another possibility is that the pipe could be crushed under debris falling from closer to shore. The design of the offshore pipes can include features to alleviate these risks, but their nature will depend on the specific risks uncovered during the offshore survey.

6.3. BUILDING RETROFIT

Makai's SWAC model assumes that all cooling customers use a chilled water (also known as hydronic) air conditioning system. Chilled water cooling uses a mechanical chiller to produce cold water at 6-7°C. This chilled water is circulated around the customer's facility and is utilized by fan coil units, air handling units, or chilled beams to cool the conditioned spaces. The additional data gathered in Montego Bay (see section 2.1) showed three hotels that use direct expansion air handling units, mini-split units, and window units.

Direct expansion air handling units are large air conditioners typically placed on the roof of buildings. These air conditioners often take air from multiple spaces within a building and use the evaporator coils of the refrigerant to cool and dehumidify the air before returning it to the building.



Figure 6-7: Example of a Rooftop Air Handling Unit

Mini-split and window units are typically used to cool individual rooms. Mini-splits have the evaporator and condenser in separate locations with refrigerant piping connecting them. The condenser is usually located outside with an integral fan for condenser cooling. The evaporator is located within the room. Unlike a full split-unit, which usually has ducts that direct cool air into multiple rooms within a building, a mini-split is usually ductless and cools only the room where it is located.





Figure 6-8: Example of Mini-Split Air Conditioning Systems

Window units are small self-contained air conditioners. They are placed within a window with the condenser portion outdoors and the evaporator portion indoors. They cool only the room in which they are located.



Figure 6-9: Example of Window Unit Air Conditioners

Any building using one of the above three systems will need to be retrofit before it can be connected to a SWAC system. Air handling units will be the easiest components to retrofit – the direct expansion equipment that currently feeds the air handlers would be replaced with chilled water equipment. Some modification to the air handlers may also be required. The mini-split and window units will require more extensive modifications if the areas they serve are to be cooled with SWAC. These units are typically small – on the order of 1-3 tons. Each one will require chilled water distribution pipes and new cooling equipment. The cost and feasibility of the retrofit cannot be determined without a detailed visit to each resort. In the United States, retrofit of cooling systems are estimated based on the floor plan area of a building, and can cost up to \$200/m². Makai recommends that CAF hire an HVAC design firm during the next phase of analysis and ask them to evaluate the retrofit feasibility and cost for each resort to be connected to a SWAC system in Montego Bay and Puerto Plata. Retrofit costs were not included in Makai's economic analysis.

Retrofitting customer's buildings introduces a new set of questions:

- Who will pay for and maintain the upgrades the owner of the SWAC utility or the owner of the building?
- If the building owner is to be responsible for upgrades, how can the SWAC utility incentivize building owners to make the changes?
- How will the need for retrofit affect the SWAC system construction and operation timetable?
- How many building owners will refuse to upgrade their equipment?

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN

Cs



The risks posed by building retrofit to the SWAC developer relate to capital cost and system size. If the SWAC developer will be responsible for the retrofit costs, then the capital cost of the SWAC system will increase. It may be possible to offset the extra capital expense in the cooling sales contract with retrofit customers. It is also possible that the owners of buildings that require retrofit will not be interested in connection to the SWAC system. This reduces the total size of the system, which adversely impacts profitability. Makai investigated the impact of reduced load in sections 5.1.1 and 5.2.2.



7. MARKETING PLAN

Makai worked with Climespace to develop a marketing strategy for a SWAC system. Climespace is an experienced district cooling operator that has been supplying cooling to customers in the heart of Paris since 1991. This section is a discussion on their experience with marketing strategies for district cooling and how such strategies can be applied in Montego Bay and Puerto Plata.

7.1. CUSTOMER PROFILES

District cooling customers can be categorized by how they utilize cooling. Basic customers have significant daily load variation. Basic customers include hotels, universities, cinemas, airports, shopping centers, and office buildings. In most district energy systems, these customers require between 1500 and 3500 full-load cooling hours annually (17% - 40% average utilization). The Caribbean differs from other areas serviced by district energy in that consistently high temperatures and humidity keep the annual average cooling loads high. Hotels have been estimated to have a 5690 full-load cooling hours annually (65% average utilization), and commercial buildings have been estimated to have 4190 full-load cooling hours annually (48% average utilization).

A more valuable category of customer includes industrial entities, hospitals, and data centers. These customers have even load curves that require extensive cooling 24 hours per day. An even load curve results in higher revenue per ton of installed load and increase the profitability of a district energy cooling system. The Caribbean again differs from typical district energy sites. There is little industrial load available in Montego Bay or Puerto Plata; the only example being the Bogue Power Station in Montego Bay (if turbine inlet cooling is installed). The cooling demand of Caribbean hospitals is not as high as that found in the United States or France, so they may not fall into the valuable customer category. No data centers are currently located in Montego Bay or Puerto Plata, but the low cost of cooling provided by SWAC may be used to attract them. It may be valuable to investigate the local data infrastructure in the Caribbean to determine of Montego Bay or Puerto Plata could host a data center.

7.1.1. Load Segmentation

The majority of the load in Montego Bay, and the entire load in Puerto Plata, are of the basic customer type. The only customer with an even load curve is the Bogue Power Station in Montego Bay. Table 7-1 shows the load segmentation in Montego Bay, and Table 7-2 shows the load segmentation in Puerto Plata.

	Segmentation			
	Estimated Load (Tons)	%		
Hotels-Resorts	5176	67		
Airport	1500	20		
Shopping Centers	100	1		
University	500	7		
Industrial	400	5		
Total	7676			

Table 7-1: Load Segmentation in Montego Bay

	Segmentation						
	Estimated Load (Tons)						
Hotels-Resorts	6835	100					

Table 7-2: Load Segmentation in Puerto Plata

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



Although neither site will be able to take advantage of high-value customers with even load curves, the unique climate of the Caribbean makes basic customers more profitable, which offsets the lack of industrial loads.

7.2. <u>SWAC DEVELOPMENT STRATEGY</u>

Development of Caribbean SWAC requires a two-pronged approach: attraction of developer interest and market preparation. Attracting developer interest will require educating developers about the opportunity presented by SWAC, and creating an environment where they can get access to the capital required to create a SWAC system. Preparation of the market will require educating potential SWAC customers, getting the cooperation of local stakeholders in the cooling and energy production industries, and getting government support to speed up the development process.

7.2.1. Developer Interest

Seawater air conditioning has several advantages over conventional cooling. These advantages create the opportunity for SWAC to undercut conventional cooling prices, and should be used to attract investment capital and developer interest to the region. The advantages include:

- Improved energy efficiency SWAC uses 10%-20% of the electricity of conventional cooling. This significantly reduces the operating cost and allows a SWAC developer to sell cooling at a price that is insensitive to prevailing energy costs.
- Limitation of CO2 emissions the commercial climate on carbon production is changing. Multiple government and international agencies are working to put economic penalties on technologies that add carbon to the atmosphere. The low energy use of SWAC will allow a developer to avoid emerging carbon costs, and instead take advantage of carbon credits used to reward low-carbon technologies.
- No use of refrigerant refrigerant fluids used in conventional chillers have traditionally been environmentally toxic, able to deplete the ozone layer and acting as greenhouse gasses. Refrigeration codes are in continuous flux as older, more toxic fluids are outlawed and newer and more expensive fluids are mandated. Regulation of refrigerants has also increased, with laws controlling how they are obtained, transported, and disposed of. Since SWAC uses no mechanical chilling, all of these regulatory hurdles are avoided. This simplifies the operation of a SWAC system compared to conventional cooling, and avoids the risk of future changes to refrigerant regulations.

The largest disadvantage of SWAC is the large up-front capital cost. SWAC is 6-9 times more expensive than conventional cooling, which represents a significant risk to a developer. An important tool in mitigating this risk is high-confidence cost estimates. Early-stage SWAC cost estimates have high uncertainty and include large contingency costs. Completion of a high-resolution bathymetric survey would allow a detailed SWAC system conceptual design with a higher confidence cost estimate. No amount of design work can avoid all cost risks (contractor bidding anomalies, environmental permitting challenges, commodity price fluctuations, etc), but a full conceptual design based on high-resolution bathymetry will be of great value to developers.

7.2.2. Market Preparation

The fundamental advantages of a SWAC system are not of any value if a developer cannot convert them into a profit. Profitability of a SWAC system is contingent on getting potential cooling customers to recognize the economic advantage of connecting to the district network. The opportunities of interest to the potential SWAC market include:


- Use of local resources Makai recommends using local contractors for as much of the work as
 possible. This supports the local economy, which stakeholders and governments see as
 positive. It also keeps the capital costs for the project down, which is helpful for developers.
- Climate change any current discussion about energy use includes the topic of climate change. There is a growing interest in energy efficiency in the general populace, and this had translated into an interest by industries that serve the populace, including resorts and commercial facilities. Connection to a SWAC system, particularly in tropical island locations, can represent a major energy savings. This savings can be advertised to resort customers for a competitive advantage over other resorts that use conventional cooling.
- Development of local expertise district cooling systems, including SWAC, requires lager facilities than do site-specific cooling systems. The design and installation of these facilities will require local companies to expand their capabilities, which will improve the commercial and industrial capabilities of the area. This expanded capability can be exported to neighboring cities, or even islands.
- Reduction in industrial equipment cooling equipment is loud and requires maintenance. A
 facility that connects to a SWAC system need not operate or maintain mechanical chillers. This
 improves the atmosphere of the facility, which is a premium benefit to resorts, and reduces
 maintenance costs.
- System reliability A SWAC system can replace dozens (or even hundreds) of individual pieces of cooling equipment. The SWAC system has only few major moving parts (the seawater pumps and chilled water pumps), which it is recommended be installed with on-line backup that automatically compensates for failures. The remainder of a SWAC system consists of static components (pipes) and components that require infrequent maintenance (valves and meters). The significant reduction in the number of components that require maintenance reduces the likelihood of failure. The centralization of all components reduces response time to failure and allows for more consistent maintenance. The end result is improved system uptime compared to site-specific cooling technology.

There are also market-based threats to the long term economic viability of a SWAC system. These threats must be taken into account when creating the SWAC business plan. Some threats include:

- Decrease in the price of electricity SWAC is most economical when electrical rates are high. If
 electrical rates decrease, then conventional cooling costs decrease significantly, but SWAC
 costs only decrease slightly. If the fall in electrical rates comes during (or before) the design
 phase of the SWAC system, then the predicted profitability of the system will fall, and the
 developer may lose interest. For an already installed SWAC system with contracted customers,
 a falling electrical rate will erode the perceived value of connection to the SWAC system.
- Hurricanes and earthquakes a SWAC system is subject to natural disasters as much as any
 facility in the area. Makai typically designs the offshore portions of a SWAC system to withstand
 the most severe conditions expected within 100 years, and recommends that the onshore
 facilities be designed to the same standard. With this approach, the SWAC system is likely to
 survive events that its customers do not.
- Insolvency of customers a SWAC system requires a minimum load to maintain profitability. If customers leave the system due to bankruptcy, natural disaster, or for other reasons, SWAC system revenue will drop. At some point, the revenue will drop to the point that the debt service on capital cost cannot be paid, and the system will become unprofitable.



7.3. CUSTOMER-UTILITY RELATIONSHIP

The relationship between the SWAC utility and its customers must be tailored to maintain SWAC developer profit while enticing customers to connect to the system. The relationship can be structured in terms of the customer requirements and rate structure

7.3.1. Customer Requirements

The customer requirements will define what the SWAC system must deliver in order to provide adequate cooling and dehumidification. The requirements will include:

- Peak cooling load the peak is the maximum amount of cooling that the SWAC system must be able to deliver to the customer. This will typically be the maximum expected cooling demand on the customer's facility during the peak cooling day. Most of the time, the SWAC system will deliver less than the peak amount of cooling.
- Supply temperature each customer's cooling equipment will have a maximum allowable chilled water supply temperature. Exceeding this temperature will cause the equipment to provide inadequate cooling, inadequate dehumidification, or both. Therefore, the SWAC system must provide the required temperature (or colder) at all times, regardless of the cooling load.
- Flow rate each piece of the customer's cooling equipment will have a flow rate requirement. This requirement may be a function of cooling load (for modern equipment), or be constant (for older equipment). The SWAC system must provide the required flow to the customer at all cooling levels.

Some of the customer requirements discussed above may be flexible, even if the customer does not realize it. The SWAC utility employees are likely to have a more sophisticated understanding of cooling systems than do those of the customers (similar to how electrical utilities have a better understand of electrical consumption than their customers). The utility can offer services to customers to help them manage their requirements, to the benefit of the SWAC system. Some options include:

- Evaluation of existing cooling equipment the utility can offer to inspect customer facilities to identify if updating some cooling components could improve the efficiency of the system. The upgrades could reduce peak cooling load, increase supply temperature, or decrease flow rate.
- Optimization of cooling control schemes the utility can evaluate how customer cooling systems are controlled, and make recommendations for more efficient control schemes. The benefit could be a reduction in peak cooling load or in annual average utilization.
- Installation of cooling load monitoring equipment customers may not realize how cooling is in use (or is wasted) at their facility. A monitoring system can reveal opportunities for system optimization.

Some of the above options have a direct benefit to the utility, particularly those that decrease peak cooling load or flow rate. Both options free up capacity for new customers to be added to the system. These options should be encouraged with rate structure incentives as discussed in the next section. Other options, such as those that reduce annual average cooling usage without decreasing peak load, may not be of obvious benefit to the SWAC utility. These options can be used to generate customer satisfaction (which could result in interest from new customers), or to diversify the total cooling load by shifting demand away from peak times (which frees up capacity that can be sold to new customers).

7.3.2. Rate Structure

The rate structure describes how customers will be charged for cooling. This structure is vital in successfully marketing SWAC to potential customers, and must be tailored to each customer's specific needs. Some of the rate structure considerations include:

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



- Term Climespace recommends a contract period of 10 years with a renewal option every 5 years. The contract term is vital to SWAC because a steady, long-term customer base is required to pay for the debt service on the capital investment. Reductions in load do not translate into large reductions in SWAC operating costs.
- Existing equipment most customers will have existing cooling equipment that represent a significant capital investment. If SWAC is to replace this equipment, the rate structure may need to reflect the value of this equipment. Some options include:
- The SWAC utility purchases the used cooling equipment. The equipment could be used to create on-line backup in case of seawater system failure (although Makai considers seawater system failure to be unlikely). It could also be used to create a mobile response unit capable of supplying emergency cooling to individual customers.
- The early-term rate structure could be discounted to offset the capital investment the customer has already made. The discount can be customized to reflect the age and power of the existing cooling equipment.
- The total rate can be broken down into three categories: a fixed charge, a demand charge, and a usage charge.
- Fixed charge covers the fixed costs of delivering cooling to customers. Examples include portions of the cost of the seawater pipe system, heat exchangers, and distribution system.
- Demand charge covers the costs associated with delivering a particular amount of cooling to a customer. This is intended to include the incremental costs of installing distribution pipes, pumps, and heat exchangers to supply each customer. It is recommended that the seawater pumping system be operated at constant volume, so the cost of electricity to run the seawater pumps would also be included in the demand charge.
- Usage charge covers the variable cost per liter of chilled water delivered to the customer. This includes the cost of the electricity required to pump the chilled water to each customer.
- Rate structure tuning the relative ratio of the three components of the rate charged to customers does not have to reflect the actual cost ratios of the utilities. For example, the usage charge can be raised to encourage energy conservation within each customer. Climespace recommends that the fixed charge be 40% of the total rate, and that the sum of the demand charge and usage charge be 60% of the total rate.
- Rate structure incentives the SWAC utility can offer rate incentives to encourage customers to adopt practices that benefit SWAC system profitability. Some examples include average utilization, load curve adherence, and flow rate variability.
- Average utilization customers with high average utilization consume more chilled water per year (without requiring an increase in overall system size) than customers with low average utilization. The fixed charge and/or demand charge for these customers could be lowered in order to attract more of them.
- Load curve adherence customers that use more cooling during off-peak times allow the SWAC utility to sell more chilled water during times when the system is under-utilized. A customer that adheres to a load curve that benefits the SWAC system (makes high use of offpeak times) may be offered discounted rates.
- Flow rate variability the variable cost of operating a SWAC system is sensitive to the flow rate
 requirements of customer equipment. In the worst case scenario, all customer equipment
 operates at constant flow and the utilities operating costs are insensitive to cooling load. In such
 a case, the usage charge collected by the utility drops during off-peak times, but the cost to
 operate the system does not change. In the best case scenario, customer cooling equipment
 varies flow rate linearly with cooling load, and the utilities operating costs go down during off-



peak times. The utility can offer discounts that encourage customers to make use of cooling components that reduce their flow rate during low-load conditions

 Flow rate reduction – modern cooling equipment is able to obtain the same amount of cooling as older equipment, but at a reduced flow rate. Since SWAC cooling capacity is limited by flow, any reduction in customer flow rate requirements represents liberated cooling capacity. If enough customers decrease their flow (without decreasing their cooling usage), then new customers could be added to the SWAC system without having to increase the output of the cold water intake pipe or distribution system. The rate structure could offer discounts to customers who installed updated lower-flow cooling components.



8. CONCLUSIONS

8.1. MONTEGO BAY

- Installation of a SWAC system is expected to be technically viable, but actual costs and feasibility
 of the system will depend on more detailed bathymetric and site conditions. Makai has designed
 and installed deep HDPE intake pipes in conditions similar to those expected offshore of
 Montego Bay, and multiple pipe design options have been developed to accommodate various
 seabed features. The general characteristics of the preliminary Montego Bay SWAC system
 include:
 - a. Cold water intake depth = 879m
 - b. Intake temperature = $6.2^{\circ}C$
 - c. Temperature delivered to customers = 7.2° C
 - d. Intake pipe length = 4.5km
 - e. Intake pipe diameter = 1200mm
 - f. Number of potential customers = 18
 - g. Peak cooling load = 7676 tons
 - h. Distribution system total length = 41.2km
- 2. A SWAC system in Montego Bay, Jamaica is likely to be cost effective. The simple payback period is predicted to be 6 years assuming a cost of electricity of \$0.36kWh.
- 3. A Montego Bay SWAC system does not benefit from the use of hybrid SWAC or installation of a thermal energy storage system.
- 4. Makai assessed the sensitivity of a SWAC system in Montego Bay to total installed load and electrical rate. A 50% reduction in electrical rate increases the simple payback period to 8.7 years. A 50% reduction in installed load increases the simple payback period to 8.9 years.
- 5. A detailed bathymetric survey is recommended before further offshore pipe design is carried out.
- 6. Resort hotels in Montego Bay are wary of inquiries relating to cooling equipment, cooling cost, and energy use. Makai recommends that CAF include local stakeholders in the SWAC planning process.
- 7. Montego Bay is at risk for a direct hit from a category 5 hurricane. The SWAC system should be designed handle the loads with such a storm. The offshore pipe will likely require post-deployment anchoring in the shallower near shore zones.
- 8. The Global Seismic Hazard Assessment Program (GSHAP) rates Montego Bay as having moderate seismic risk. The predicted ground accelerations are 2.9 m/s², and onshore structure design should take that level of seismic event into account. Makai recommends that a geotechnical survey be carried out before detailed design work on the offshore pipes begins. A marine geotechnical engineer should be hired to evaluate the results of the geotechnical survey and provide design conditions for the pipes.

8.2. <u>PUERTO PLATA</u>

Installation of a SWAC system is expected to be technically viable, but actual costs and feasibility
of the system will depend on more detailed bathymetric and site conditions. Makai has designed
and installed deep HDPE intake pipes in conditions similar to those expected offshore of Puerto
Plata, and multiple pipe design options have been developed to accommodate various seabed
features. The general characteristics of the preliminary Puerto Plata SWAC system include:

a. Cold water intake depth = 1082m

A PRE-FEASIBILITY STUDY FOR DEEP SEAWATER AIRCONDITIONING SYSTEMS IN THE CARIBBEAN



- b. Intake temperature = $5.8^{\circ}C$
- c. Temperature delivered to customers = $7.2^{\circ}C$
- d. Intake pipe length = 8.0km
- e. Intake pipe diameter = 1100mm
- Number of potential customers = 16 f.
- g. Peak cooling load = 6835 tons
- h. Distribution system total length = 13.4km
- 2. A SWAC system in Puerto Plata, the Dominican Republic is likely to be cost effective. The simple payback period is predicted to be 4.5 years.
- 3. Makai assessed the sensitivity of a SWAC system in Puerto Plata to total installed load and electrical rate. A 50% reduction in electrical rate increases the simple payback period to 6.7 years. A 50% reduction in installed load increases the simple payback period to 6.9 years.
- 4. A SWAC system in Puerto Plata does not benefit from hybrid SWAC, but does benefit from installation of a thermal energy storage system.
- 5. A detailed bathymetric survey is recommended before further offshore pipe design is carried out.
- 6. Resort hotels in Puerto Plata are wary of inquiries relating to cooling equipment, cooling cost, and energy use. Makai recommends that CAF include local stakeholders in the SWAC planning process.
- 7. Puerto Plata is at risk for a direct hit from a category 5 hurricane. The SWAC system should be designed handle the loads with such a storm. The offshore pipe will likely require postdeployment anchoring in the shallower near shore zones.
- 8. The Global Seismic Hazard Assessment Program (GSHAP) rates Puerto Plata as having high seismic risk. The predicted ground accelerations are 3.2 m/s², and onshore structure design should take that level of seismic event into account. It is recommended that a geotechnical survey be carried out before detailed design work on the offshore pipes begins. A marine geotechnical engineer should be hired to evaluate the results of the geotechnical survey and provide design conditions for the pipes.